

From: Nathan Hodges [REDACTED]
Sent: 06 July 2021 18:15
To: Charlotte Meynell
Cc: James Prestedge; John Brady
Subject: HPRM: RE: 2021/1989 - City House, 72-80 Leather Lane, London, EC1N 7TR - Further info required
Attachments: [W632-M-101-C1.pdf](#); [W632-M-102-C1.pdf](#); [TwinFans-Squif.pdf](#)
Follow Up Flag: Follow up
Flag Status: Flagged
Categories: Red Category
Record Number: PLD/21/59051

[EXTERNAL EMAIL] Beware – This email originated outside Camden Council and may be malicious Please take extra care with any links, attachments, requests to take action or for you to verify your password etc. Please note there have been reports of emails purporting to be about Covid 19 being used as cover for scams so extra vigilance is required.

Hi Charlotte,

Fan Ventilation Spec:
Nuair SQFTA41-1 twin fan / 300l/s@125pa – please see attached BSDa drawings W632-M-101-C1 and W632-M-102-C1. Manufacturer's details can also be found within the attached "TwinFans-Squif" pdf.

Odour Filtration:
The proposal is to install a carbon cannister at high level within the basement so as to ensure ease of access / maintenance. The carbon cannister will be by AAC Eurovent <https://www.aaceurovent.co.uk/aac-ccg-ss-carbon-canisters/> who will design the cannister to suit site requirements.

Insect Mesh
A weather louvre will be installed to the 250mm diameter with vermin and insect mesh as per https://www.cveshop.co.uk/cveshophome/prod_2364796-CVCWL250-Circular-Weather-Louvre.html

Regards,

Nathan Hodges BA(Hons) Dip Arch RIBA
Director

[REDACTED]
w. <http://www.hodgesarchitects.co.uk>