
Iesis Special Structures Limited
20 Ironmonger Lane
London
EC2V 8EP

t: +44 (0)207 600 2912
w: www.iesisgroup.com
e: iss@iesisgroup.com

IESISSTRUCTURES

Our ref: SE1229/xx/210715/gm

15th July. 2021

To whom it may concern,

RE: 156, West End Lane – Planning condition 17, Impact Piling

The above planning condition notes that a full method statement is required prior to any impact piling taking place on the development.

The current permanent works design incorporates Continuous Flight Auger piles acting as the foundation solution to the scheme. These piles are widely known as replacement piles, no typically considered impact piling is included within the design.

As per the above it is therefore considered that no method statement is required to satisfy this condition.

We trust the above answers your queries, if you have any further questions please get in touch.

Yours faithfully,

George McGrath



MEng(Hons) CEng MIstructE
Associate



LONDON • BRISTOL • MANCHESTER

IESISGROUP