

Land between Gondar House
and South Mansions

Basement Impact Assessment
Audit

For

London Borough of Camden

Project Number: 13693-02

Revision: F1

July 2021

Campbell Reith Hill LLP
15 Bermondsey Square
London
SE1 3UN

T: +44 (0)20 7340 1700
E: london@campbellreith.com
W: www.campbellreith.com

Document History and Status

Revision	Date	Purpose/Status	File Ref	Author	Check	Review
D1	June 2021	For comment	KBgk13693-02-23062021-32 Land between Gondar House and South Mansions-D1.doc	KB	GK	GK
F1	July 2021	For Planning	KBgk13693-02-020721-32 Land between Gondar House and South Mansions-F1.doc	KB	GK	GK

This document has been prepared in accordance with the scope of Campbell Reith Hill LLP's (CampbellReith) appointment with its client and is subject to the terms of the appointment. It is addressed to and for the sole use and reliance of CampbellReith's client. CampbellReith accepts no liability for any use of this document other than by its client and only for the purposes, stated in the document, for which it was prepared and provided. No person other than the client may copy (in whole or in part) use or rely on the contents of this document, without the prior written permission of Campbell Reith Hill LLP. Any advice, opinions, or recommendations within this document should be read and relied upon only in the context of the document as a whole. The contents of this document are not to be construed as providing legal, business or tax advice or opinion.

© Campbell Reith Hill LLP 2021

Document Details

Last saved	06/07/2021 11:00
Path	KBgk13693-02-060721-32 Land between Gondar House and South Mansions-F1.doc
Author	K Barker, MSci CGeol FGS
Project Partner	E M Brown, BSc MSc CGeol FGS
Project Number	13693-02
Project Name	Land Between Gondar House and South Mansions
Planning Reference	2020/3553/P & 2021/2596/P

Contents

1.0 Introduction 1

2.0 Discussion 2

Appendix

- Appendix 1: Residents' Consultation Comments
- Appendix 2: Audit Query Tracker
- Appendix 3: Supplementary Supporting Documents

1.0 INTRODUCTION

- 1.1. CampbellReith was instructed by London Borough of Camden, (LBC) to carry out an audit on a revised Ground Movement Assessment submitted as part of the Planning Submission documentation for revisions to a previously audited scheme for the Land between Gondar House and South Mansions, London NW6 1QD (planning reference 2021/2596/P, original planning reference 2020/3553/P). The basement is considered to fall within Category B as defined by the Terms of Reference.
- 1.2. The Audit reviewed the updated Ground Movement Assessment (GMA) for potential impact on land stability arising from basement development in accordance with LBC's policies and technical procedures. Impacts to local ground and surface water conditions are presented in the original audit report by CampbellReith, ref. KBemb13398-45-170221-Land between Gondar House and South Mansions F1, dated 17 February 2021.
- 1.3. CampbellReith was able to access LBC's Planning Portal and gain access to the following relevant documents for audit purposes:
 - Letter Report by Card Geotechnics Ltd, ref. CG/28978c, dated 24 May 2021.
 - Structures Stage 2 Report by SD Structures, revision 3, dated 24 May 2021.
 - Planning Application drawings including proposed plan and section drawings, all dated 25 May 2021.
- 1.4. The following additional document was provided to CampbellReith in response to the queries raised in Appendix 2:
 - Structures Stage 2 Report by SD Structures, revision 4, dated 28 June 2021.
- 1.5. The changes to the original scheme comprise reducing the overall footprint of the building and reducing the excavation depth of the basement.
- 1.6. The updated GMA has been prepared by Card Geotechnics Ltd and the authors possess suitable qualifications that comply with the requirements of CPG: Basements.
- 1.7. The revised Structural Stage 2 Report (SSR) has now been updated to reflect the changes that were agreed as part of the original audit report.
- 1.8. Based on the revised submission it can be confirmed that the GMA meets the criteria of CPG: Basements.

2.0 DISCUSSION

- 2.1. The updated Ground Movement Assessment (GMA) has been prepared by Card Geotechnics Ltd (CGL) and authors possess suitable qualifications that comply with the requirements of CPG: Basements.
- 2.2. The revised proposal comprises the following:
1. Slight adjustments to the layout of the basement and building footprint.
 2. Raising the basement floor elevations from -1.71m to -0.803m from Site Datum (SD) and from -3.05m to -1.33m SD.
 3. The inclusion of a permanent prop to support the lightwell.
- 2.3. A review of the submitted drawings shows the change to the basement footprint will not bring the line of the contiguous pile wall closer to the neighbouring building than the original scheme.
- 2.4. The GMA considers the impact of the revised scheme on each of the critical sections analysed in the BIA for the original scheme. For critical sections 1 and 1a, the GMA letter concludes that, due to the reduction in the basement depth, the impact to these buildings would not increase from that assessed in the original BIA. For critical sections 3 and 4, the GMA letter concludes that, due to the reduction of the basement footprint the impacts to these buildings would not be more onerous than the impacts assessed in the original BIA.
- 2.5. Critical Section 2 has been reassessed due to the proposal to use two steel permanent props to support the lightwell adjacent to the outbuilding for No. 3 Hillfield Road. A Wallap analysis is provided, which shows the anticipated deflection of the wall during basement construction. This data is used to calculate the anticipated ground movements experienced by the adjacent structure. The GMA identifies that an increase in the deflection ratio is anticipated, but that this increase does not cause damage to the adjacent structure to exceed Burland category 1 (Very Slight).
- 2.6. Section 6.3 of the Structures Stage 2 Report (SSR) discusses monitoring of the adjacent buildings during construction. The revised SSR submission now includes updated trigger level values which reflect the correspondence and values agreed during the initial BIA audit for the original scheme.
- 2.7. It is noted that the SSR also uses ground movement data from the BIA for the previous scheme, which should be updated. However, as described in 2.4 and 2.5, the revised scheme is shown as not resulting in more onerous building damage to neighbouring properties.

- 2.8. Based on the revised submission it can be confirmed that the scheme meets the criteria of CPG:
Basements.

Appendix 1: Residents' Consultation Comments

None

Appendix 2: Audit Query Tracker

Audit Query Tracker

Query No	Subject	Query	Status/Response	Date closed out
1	Stability	The Structures Stage 2 Report should be updated to reference the most up to date version of the BIA and present the monitoring trigger levels that were agreed by SD Structures during the original audit for the property.	Closed	July 2021

Appendix 3: Supplementary Supporting Documents

None

London

15 Bermondsey Square
London
SE1 3UN

T: +44 (0)20 7340 1700
E: london@campbellreith.com

Birmingham

Chantry House
High Street, Coleshill
Birmingham B46 3BP

T: +44 (0)1675 467 484
E: birmingham@campbellreith.com

Surrey

Raven House
29 Linkfield Lane, Redhill
Surrey RH1 1SS

T: +44 (0)1737 784 500
E: surrey@campbellreith.com

Manchester

No. 1 Marsden Street
Manchester
M2 1HW

T: +44 (0)161 819 3060
E: manchester@campbellreith.com

Bristol

Wessex House
Pixash Lane, Keynsham
Bristol BS31 1TP

T: +44 (0)117 916 1066
E: bristol@campbellreith.com

Campbell Reith Hill LLP. Registered in England & Wales. Limited Liability Partnership No OC300082
A list of Members is available at our Registered Office at: 15 Bermondsey Square, London, SE1 3UN
VAT No 974 8892 43