

Application ref: 2020/4907/P
Contact: Matthew Dempsey
Tel: 020 7974 3862
Email: Matthew.Dempsey@Camden.gov.uk
Date: 28 July 2021

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

Mahir Kilic
Narts
53 Stoke Newington High St
London N16 8EL

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:

Unit 2
10 Bloomsbury Way
London
WC1A 2SL

Proposal:

Installation of extractor unit with ventilation flap installed behind existing louvre.
Drawing Nos: Site Location and block Plan (24/11/2020), Existing ground floor plan, Proposed ground floor plan, Existing and Proposed front elevation. Design and Access statement (Nov 2020), Noise Assessment (Nov 2020), Electrostatic Precipitator Technical and Operation Manual, Odour Control Guide.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the

following approved plans- Site Location and block Plan (24/11/2020), Existing ground floor plan, Proposed ground floor plan, Existing and Proposed front elevation. Design and Access statement (Nov 2020), Noise Assessment (Nov 2020), Electrostatic Precipitator Technical and Operation Manual, Odour Control Guide.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 Prior to use, machinery, plant or equipment and ducting at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration isolated from the casing and adequately silenced and maintained as such.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 4 Noise levels at a point 1 metre external to sensitive facades shall be at least 10dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 15dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Reasons for granting permission:

The proposed development is considered to be a very minor alteration to the existing arrangement and is considered acceptable in terms of location, design and materials. Three new extractor units shall be installed behind an existing louvre and will not be noticeable from the public realm thus would have no impact on the character and appearance of the host building, streetscene and conservation area. Due to the location and limited nature of the proposed works, the proposals would not impact neighbouring amenity by way of loss of outlook, daylight or noise nuisance.

A planning noise assessment has been submitted which shows that the plant will comply with the Council's noise standards in terms of being at least 10dBa below background noise levels.

No objections were received prior to the determination of this application. The planning history of the site has been taken into account when coming to this decision.

Special attention has been paid to the desirability of preserving or enhancing the character or appearance of the conservation area, under s.72 of the Planning (Listed Buildings and Conservation Areas Act 1990) as amended by the Enterprise and Regulatory Reform Act 2013.

As such, the proposed development is in general accordance with policies D1, D2, A1 and A4 of the Camden Local Plan 2017. The proposed development also accords with the London Plan 2021 and the National Planning Policy Framework 2019.

- 2 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 3 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444). Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.
- 4 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website (search for 'Camden Minimum Requirements' at www.camden.gov.uk) or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2019.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink, appearing to read 'DPope', is positioned in the upper left quadrant of the page. The signature is fluid and cursive.

Daniel Pope
Chief Planning Officer