

Conservation Area Advisory Committee

Advisory Committee	Belsize
Application ref	2021/2943/P
Address	Tudor Close Tudor Close Belsize Park NW3 4AG
Planning Officer	Ewan Campbell
Comments by	15 Aug 2021
Proposal	Full Planning Permission for the installation of 6x tiled and hipped roofs to top of bays to front of Tudor Close (flats 43-60 block) to prevent water ingress.
Objection	Yes
Observations	<p>OBJECT</p> <p>Object to new pitched roofs over existing flat parapets to bay windows.</p> <p>These pitched roofs abut awkwardly with the existing openings in gable ends and leave insufficient surface around the windows.</p> <p>Membranes over flat roofs can be watertight.</p> <p>Eldred Evans Chair BCAAC</p>

Documents attached

No details entered

About this form

Issued by	Contact Camden 5 Pancras Square London N1C 4AG
Form reference	21703603

Data Protection

Data Protection

No personal information you have given us will be passed on to third parties for commercial purposes. The Council's policy is that all information will be shared among officers and other agencies where the legal framework allows it, if this will help to improve the service you receive and to develop other services. If you do not wish certain information about you to be exchanged within the Council, you can request that this does not happen.