From: Sent: To: Cc: Subject:	DEVELOPER.SERVICES@THAMESWATER.CO.U <developer.services@thameswater.co.uk> 19 August 2021 15:40 nathan.town@fhpp.com; Chris McGovern aaron.plank@thameswater.co.uk 156 West End Lane, West Hampstead, London, NW6 1SD - DS6086622 - Capacity Approval</developer.services@thameswater.co.uk>
Good afternoon Nathan and Chris,	
Many thanks for both of you	our time on our calls this afternoon.
•	acity has been approved for the connections at 156 West End Lane, West 1SD after speaking with relevant departments. I have discussed if this can ng and confirmed it can.
The average flowrates thro	ough each pipe below as requested:
• 90mm = 20.2 litres per se	econd
• 32mm = 1.15 litres per se	econd
Our minimum guarantee is	s 1 bar pressure, 9 litres per minute and 10m head.
I hope the above informat hesitate to contact me.	ion helps you, if you do have any further queries with this, please do not
Kind regards,	

Aaron Plank
Developer Services - Design Estimator
Helpdesk 0800 009 3921
aaron.plank@thameswater.co.uk
Clearwater Court, Vastern Road, Reading, RG1 8DB
Find us online at developers.thameswater.co.uk



Visit us online <u>www.thameswater.co.uk</u>, follow us on twitter <u>www.twitter.com/thameswater</u> or find us on <u>www.facebook.com/thameswater</u>. We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.