

Conservation Area Advisory Committee

Advisory Committee	Belsize
Application ref	2021/3432/P
Address	Flat 4 10 Crossfield Road London NW3 4NS
Planning Officer	Jennifer Dawson
Comments by	12 Sep 2021
Proposal	Installation of a conservation (flush) roof window between dormer W3.1 and southern party wall.
Objection	Yes
Observations	<p>OBJECT</p> <p>There is insufficient space between the dormer window and party wall to house a properly designed roof light.</p> <p>Eldred Evans Chair BCAAC</p>

Documents attached

No details entered

About this form

Issued by	Contact Camden 5 Pancras Square London N1C 4AG
Form reference	21709111

Data Protection

No personal information you have given us will be passed on to third parties for commercial purposes. The Council's policy is that all information will be shared among officers and other agencies where the legal framework allows it, if this will help to improve the service you receive and to develop other services. If you do not wish certain information about you to be exchanged within the Council, you can request that this does not happen.