

| Application No: | Consultees Name: | Received: | Comment: | Response: |
|-----------------|------------------|---------------------|----------|---|
| 2021/2320/P | Mrs C V Levitt | 07/09/2021 11:33:03 | COMMNT | <p>I object to the proposal to put two air conditioning units on the roof of 15-17 South End Road, NW3 2PT. The property is directly opposite houses in Maryon Mews, NW3 2PU. These air conditioning units are above the UK government guidance on noise nuisance, which says this about permitted noise levels: "The permitted noise level using A-weighted decibels (the unit environmental noise is usually measured in) is: 34 dBA (decibels adjusted) if the underlying level of noise is no more than 24 dBA 10 dBA above the underlying level of noise if this is more than 24 dBA". We the residents of Maryon Mews are entitled to the peace and quiet enjoyments of our homes. It is also against the Local Plan and Camden's policy on noise nuisance in residential areas. I ask that this application is refused given the proximity to residential homes.</p> |
