

Application ref: 2021/0145/P
Contact: Josh Lawlor
Tel: 020 7974 2337
Email: Josh.Lawlor@camden.gov.uk
Date: 14 September 2021

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

Wildstone Planning
22 Berghem Mews
Blythe Road
Brook Green
London
W14 0HN

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Approval of Details Granted

Address:

**Central Somers Town covering Land at Polygon Road Open Space
Edith Neville Primary School,
174 Ossulston Street
and Purchase Street Open Space
NW1 1DN**

Proposal:

Details pursuant to Condition 139 (Air Quality) of planning permission ref. 2019/5882/P dated 01/07/2020 for 'Variation of conditions 2, 3, 15 and 80 of planning permission reference 2015/2704/P dated 14/10/2016 for: Demolition of existing buildings and the provision of replacement school; community facilities; flexible Class A1/A2/A3/D1 floorspace; and residential unit over 7 buildings ranging from 3 to 25 storeys in height.'
Drawing Nos: Cover Letter - condition 139 Air Quality and AQ109785 - Brill Place Tower London

The Council has considered your application and decided to grant permission.

Informative(s):

1 Reasons for granting approval-

Condition 139 relates to a statement setting out the air quality implications of connecting to the Somers Town Energy District Heating Network.

The submitted Air Quality Statement considers the impact of the Somers Town Heat Network on the development. The initial model covered all the three boilers (2 boilers +1 standby) and 1 CHP, which are all continuously in operation 24 hours a day. The Somers Town CHN provision of heat and hot water will include the implementation of 3 boilers and a 900kW CHP. It is predicted that there will be no change in energy sources or associated emissions.

The Council's Sustainability Officer has reviewed the details and confirms that they are acceptable. The statement demonstrates that the air quality implications are not materially different to those already approved for the District Heating Network.

The details are thus in accordance with the requirements of policies A1 and C1 of the Camden Local Plan 2017.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraph 38 of the National Planning Policy Framework 2021.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink, appearing to read 'DPope', is positioned above the printed name and title of the signatory.

Daniel Pope
Chief Planning Officer