

Tania Clifford

From: no-reply@camden.gov.uk
Sent: 01 October 2021 14:33
To: env.devcon@camden.gov.uk; udr@camden.gov.uk; Planning Planning
Subject: Conservation area advisory committee comments form
Attachments: 21718062.htm; 21718062.xml; 21718062.pdf

CONSERVATION AREA ADVISORY COMMITTEE

Advisory Committee: Parkhill/Upper Park
Application ref: 2021/3650/P
Address: 8 Upper Park Road London NW3 2UP Planning Officer: Enya Fogarty Comments by: 10 Oct 2021
Proposal: Construction of a rear dormer

Objection: Yes

Observations: OBJECT

The width of the dormer is excessive, it should match the window below.

If the windows are to be double glazed the glazing bars should be no larger than for single glazing.

David Thomas
for
BCAAC

DOCUMENTS ATTACHED

No details entered

ABOUT THIS FORM

Issued by: Contact Camden
5 Pancras Square
London N1C 4AG
Form reference: 21718062