

Tania Clifford

From: no-reply@camden.gov.uk
Sent: 01 October 2021 14:53
To: env.devcon@camden.gov.uk; udr@camden.gov.uk; Planning Planning
Subject: Conservation area advisory committee comments form
Attachments: 21718069.htm; 21718069.xml; 21718069.pdf

CONSERVATION AREA ADVISORY COMMITTEE

Advisory Committee: Belsize

Application ref: 2021/2409/P

Address: Flat 2 21 Glenloch Road London NW3 4DJ Planning Officer: Obote Hope Comments by: 17 Oct 2021

Proposal: Erection of a rear dormer roof extension and installation of 3 x conservation rooflight above for the use of the loft as ancillary habitable space.

Objection: Yes

Observations: OBJECTION

The extent of the dormer is excessive. The width should only be sufficient to accommodate the windows, the height should be to normal cill level and not extend down to the floor.

If the dormer windows are to be double glazed the width of the glazing bars should be no larger than for single glazing.

David Thomas
for BCAAC

DOCUMENTS ATTACHED

No details entered

ABOUT THIS FORM

Issued by: Contact Camden
5 Pancras Square
London N1C 4AG
Form reference: 21718069