

**Mohammed Ahmed**

---

**From:** no-reply@camden.gov.uk  
**Sent:** 07 October 2021 10:43  
**To:** [REDACTED]  
**Subject:** Conservation area advisory committee comments form  
**Attachments:** 21719429.htm; 21719429.xml; 21719429.pdf

CONSERVATION AREA ADVISORY COMMITTEE

-----  
Advisory Committee: Belsize  
Application ref: 2021/4082/P  
Address: 34 Glenilla Road London NW3 4AN Planning Officer: Adam Greenhalgh Comments by:  
31 Oct 2021  
Proposal: Removal of existing rooflight on side (west) roofslope and addition of rooflights on rear  
roofslope (3) and front roofslope (1).  
Alterations to front of site including new front boundary wall with railings atop, new timber bin store  
at front and cast stone paving/steps, resin paving and provision of raised planters.

Objection: Yes

Observations: Objection

The proposed gate and its posts should be no higher than the existing front garden wall.

The bin store is inappropriate in the street setting.

The front path should be permeable in accordance with SuDS recommendations.

David Thomas  
for BCAAC

DOCUMENTS ATTACHED

-----  
No details entered

ABOUT THIS FORM

-----  
Issued by: Contact Camden  
5 Pancras Square  
London N1C 4AG  
Form reference: 21719429