

30 Percy Street Booster Pump CWS Tank Schedule Revision A

Booster Pump Schedule

Ref No.	Model	Quote No.	Pressure (Bar)	Head (m)	Power Supply (230V)	Dimensions	Inlet / Outlet	Weight (KG)	Notes
Pump / Tank	Home Booster 4.5 - 200L	-	4.5	40	4A	600 x 600 x 1000mm (H)	2" BSP	240KG (Wet)	22mm Overflow
Slave	Home Booster Slave Tank - 180L	-	-	-	4A	600 x 600 x 1000mm (H)	2" BSP	240KG (Wet)	22mm Overflow

Notes

- 1. Unit to have intergral onboard controls
- 2. Pumps to be inverter driven/variable speed
- 3. Pumps to be inverter driven/variable speed
- 4. Pumps to be supplied with high and low level float switches, anti-vibration mounts and flexible connections.
- 5. Pumps to be supplied with flexible connections & vibration isolation.