Iesis Special Structures Limited 20 Ironmonger Lane London EC2V 8EP

> t: +44 (0)207 600 2912 w: www.iesisgroup.com e: iss@iesisgroup.com

Our ref: SE1229/xx/211007/gm

07th October. 2021

Julie Mc Laughlin Tetra Tech Planning 11th Floor 1 Angel Court London EC2R 7HJ

RE: 156, West End Lane - Green Roof loading requirement.

We can confirm that the green roof areas on the above development will be designed to accommodate a minimum load of 250kg/m2 as per the requirements for a green roof.

We trust the above answers your queries, if you have any further questions please get in touch.

Yours sincerely,

George McGrath



MEng(Hons) CEng MIstructE Associate





