




Part-Frank Elevation  
as Existing



Part-Frank Elevation  
as Proposed

Stack height to be a minimum of 1m above roof eaves, to ensure adequate dilution of odours to take place before the plume interacts with a receptor.

Extractor to have a minimum discharge velocity of at least 8m/s

The final discharge point needs to be vertically upwards and unhindered. The discharge point is directed to the rear.

All kitchen extract ducting must be fitted with access panels/hatches at approximately 3 metre intervals to enable cleaning and maintenance and must also comply with the safe access standards.

Extract Duct

New commercial extract flue to be installed, duct work to come out via existing opening above fire exit doors at ground floor level

**PPLX**  
Architects

58 Pine Grove  
Brookmans Park  
Herts  
AL9 7BW

t: 07886 526 081  
f: 01707 642 026  
e: papalexandrakos@hotmail.com


Site:  
181 York Way  
London  
N7 9LN

Client:  
Greek Coffee Ltd

Title:  
Part-Frank Elevation  
as Existing and Proposed

Drawn: NP | Drg. No. 307\_04

Date: Sept. 2021 | Rev. #



Scale: 1:100 | Drg. Size: A3

Key:

Existing Walls/Floors

Boundary

Rev.	Date	Note