

Application No:	Consultees Name:	Received:	Comment:	Response:
2021/5385/T	Vicki Harding	08/11/2021 17:51:53	COMMNT	<p>Neither this, nor the previous application 2021/3351/T mentioned on the application form have included any evidence of tree-related subsidence. Since the rear wall will require re-building, and this can be done with the tree present, then a decision cannot be determined if there is no evidence of subsidence causation either.</p> <p>Movement monitoring, real evidence of desiccation, and demonstration of recovery with crack closure during winter months and associated with rainfall to show the trees really are responsible should be required.</p>
