

Conservation Area Advisory Committee

Advisory Committee	Belsize
Application ref	2021/4725/P
Address	Garden and Ground Floor Flats 4 Lancaster Drive London NW3 4HA
Planning Officer	Fast Track Team
Comments by	19 Dec 2021
Proposal	Replacement of French doors on the rear lower ground floor and windows to front, rear and side elevations at lower and upper ground floors, enlargement of existing window on the rear and insertion of a new window on the side elevation at upper ground floor.
Objection	Yes
Observations	<p>Objection</p> <p>The new ground floor rear window and the side windows should be sliding sash without divisions to match the other existing windows. The window and door double glazed framing should be no larger than the existing single glazed framing.</p> <p>David Thomas for BCAAC</p>

Documents attached

No details entered

About this form

Issued by	Contact Camden 5 Pancras Square London N1C 4AG
Form reference	21729548

Data Protection

No personal information you have given us will be passed on to third parties for commercial purposes. The Council's policy is that all information will be shared among officers and other agencies where the legal framework allows it, if this will help to improve the service you receive and to develop other services. If you do not wish certain information about you to be exchanged within the Council, you can request that this does not happen.