From:

Sent: 01 December 2021 12:03

To:

Subject: 3rd Party Planning Application - 2021/5410/P

London Borough of Camden Our DTS Ref: 65167 Camden Town Hall Your Ref: 2021/5410/P Argyle Street Euston Road London WC1H 8EQ

1 December 2021

Dear Sir/Madam

Re: LIGHT INDUSTRIAL ESTATE REDEVELOPMENT SITE, LIDDELL ROAD, WEST HAMPSTEAD, LONDON, NW6 1PL

Waste Comments

Water Comments

Thank you for consulting Thames Water for the discharge of matters relating to water networks. Thames Water confirm that they are happy for the water networks condition referenced, to be discharged based on the information submitted.

Supplementary Comments

Based on the modelling study result confirm that there is capacity in the network for 106 residential flats and 3800 sqm offices the point of connection 125mm HPPE main in MAYGROVE ROAD. reference: DS6088253

Yours faithfully Development Planning Department

Development Planning, Thames Water, Maple Lodge STW, Denham Way, Rickmansworth, WD3 9SQ

Tel:020 3577 9998

Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to

devcon.team@thameswater.co.uk

Visit us online <u>www.thameswater.co.uk</u>, follow us on twitter <u>www.twitter.com/thameswater</u> or find us on <u>www.facebook.com/thameswater</u>. We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.