



Do not use these drawings to form a pit, Sesame's detailed design must be completed and approved before any pits are formed.

PLEASE NOTE THAT THE SESAME LIFT (RISERS AND TREADS) NEEDS TO BE CLAD FIRST, BEFORE THE SITE CLADDING IS PUT AROUND THE SESAME SYSTEM. IF THE AREA AROUND THE SESAME SYSTEM IS CLAD PRIOR TO THE SESAME LIFT, SESAME SYSTEM LTD. WILL TAKE NO RESPONSIBILITY FOR MISALIGNMENTS OF ALL CLADDING.

Client/Architect/Stonemason to specify the Treads Nosing's or Anti Slip Strips on the Treads to match the surrounding steps cladding details.

BS:6440:2011, 8.3 - Adjacent surfaces

For adjacent surfaces 10mm or less from any part of the carrier, any projections on the surface shall be as follows:-

a) If they include projections up to 1.5mm, they may have square corners

b) If they include projections from 1.5mm up to 5mm they shall have a minimum of 15 degrees vertical chamfers on all edges

Adjacent surfaces greater than 10mm and less than 100mm from the carrier shall have a sensitive edge, photo cell or light curtain located along any affected surfaces.

Note there is a risk of crushing if the part of the structure is less than 100mm to an adjacent surface.

To remove any crush zone risk there should be a distance of 300mm or more between the carrier and the crush zone.

Changes since rev_0:

- Layout has been changed as per BL13 DWG;
- Platform has been enlarged;
- Glass barriers have been changed on the lift;
- Sesame System has been adjusted;
- Button stations have been updated;
- Button post on the lift has been changed.

Changes since rev_1:

- Button post has been updated;
- Upper landing button station has been updated;
- Upper landing wall has been changed to glass;
- Upper landing service hatch has been updated;
- Platform service hatch has been deleted;
- Access through the Sesame pit has been added.

This drawing and the information it contains is the property of Sesame Access Systems LTD. and must not be copied or issued to any third party	Designed by K. Porwol	Checked by S.J. Lyons	Date 26/08/2020	Project Name: 0000.BritishLibraryEntranceHall	Revision 2
				3D Layout	Sheet 1 / 6