

SAP 2012 Overheating Assessment

Calculated by Stroma FSAP 2012 program, produced and printed on 24 September 2021

Property Details: 13049 - 6 Active Cooling Systems

Dwelling type:	Flat
Located in:	England
Region:	Thames valley
Cross ventilation possible:	Yes
Number of storeys:	1
Front of dwelling faces:	North
Overshading:	Average or unknown
Overhangs:	None
Thermal mass parameter:	Indicative Value Medium
Night ventilation:	False
Blinds, curtains, shutters:	None
Ventilation rate during hot weather (ach):	3 (Windows open half the time)

Overheating Details:

Summer ventilation heat loss coefficient:	301.54	(P1)
Transmission heat loss coefficient:	99.9	
Summer heat loss coefficient:	401.47	(P2)

Overhangs:

Orientation:	Ratio:	Z_overhangs:
South (Rear Windows)	0	1
East (E Windows)	0	1
North (Front Windows)	0	1

Solar shading:

Orientation:	Z blinds:	Solar access:	Overhangs:	Z summer:	
South (Rear Windows)	1	0.9	1	0.9	(P8)
East (E Windows)	1	0.9	1	0.9	(P8)
North (Front Windows)	1	0.9	1	0.9	(P8)

Solar gains:

Orientation	Area	Flux	g_	FF	Shading	Gains
South (Rear Windows)	0.9 x	13.51	112.21	0.76	0.7	653.23
East (E Windows)	0.9 x	6.85	117.51	0.76	0.7	346.86
North (Front Windows)	0.9 x	4.91	81.19	0.76	0.7	171.77
					Total	1171.86 (P3/P4)

Internal gains:

	June	July	August
Internal gains	549.57	526.84	537.04
Total summer gains	1780.73	1698.7	1626.36 (P5)
Summer gain/loss ratio	4.44	4.23	4.05 (P6)
Mean summer external temperature (Thames valley)	16	17.9	17.8
Thermal mass temperature increment	0.25	0.25	0.25
Threshold temperature	20.69	22.38	22.1 (P7)
Likelihood of high internal temperature	Slight	Medium	Medium

Assessment of likelihood of high internal temperature: Medium