




- NOTES
- ALL DRAWINGS SHALL BE READ IN CONJUNCTION WITH LONG & PARTNERS DRAWINGS, SCHEDULES & SPECIFICATION.
 - FOR DETAILS, ELEVATIONS & EXACT SETTING OUT OF WALL MOUNTED ACCESSORIES, REFER TO THE ARCHITECTS LAYOUT.
 - THE ELECTRICAL SERVICES WORKS SHALL BE CARRIED OUT IN ACCORDANCE WITH THE LONG & PARTNER'S SPECIFICATION.

- LEGEND
- CL SINGLE SWITCHED CLEANERS SOCKET OUTLET
 - TS SINGLE SWITCHED TAP SENSOR SOCKET OUTLET
 - TS TWIN SWITCHED SOCKET OUTLET
 - TS TWIN SWITCHED SOCKET OUTLET C/W TWIN USB OUTLET
 - TS TWIN METAL CLAD SWITCHED SOCKET OUTLET
 - 32 A COMMANDO SOCKET
 - SWITCHED FUSED SPUR UNIT FOR:-
 - DA - DISABLED ALARM
 - WH - WATER HEATER
 - TH - TRACE HEATING
 - SV - SOLENOID VALVE
 - LD - LEAK DETECTION
 - BMS - BMS OUTSTATION
 - EF - EXTRACT FAN
 - CI - CISTERNESTERS
 - FCU - FAN COILS UNIT
 - UH - UNDERFLOOR HEATING
 - AC - ACCESS CONTROL
 - R - PA/VA RACK
 - FAP - FIRE ALARM PANEL
 - DX - WALL MOUNTED AC DX UNIT
 - DW - DISHWASHER
 - Z - ZIRTIAP
 - F - Fridge
 - MW - MICROWAVE
 - Single Switched Socket Floor Grommet
 - 110v
 - 110v SOCKET OUTLET C/W TRANSFORMER
 - DATA OUTLETS - 'N' DENOTES THE NUMBER OF GANG
 - AC DATA OUTLET - ACCESS CONTROL
 - DR DATA OUTLET - DISABLED REFUGE INTERCOM
 - RB DATA OUTLET - ROOM BOOKING PANEL
 - ISOLATOR (RATINGS AS NOTED ON DRAWINGS)
 - EARTH BONDING TO:-
 - W - MET SERVICES
 - F - FLOOR TILES
 - C - CEILING TILES
 - DISABLED ALARM RESET UNIT
 - DISABLED ALARM REMOTE INDICATOR/BEACON UNIT
 - DISABLED ALARM PULL CORD
 - DISABLED REFUGE INTERCOM UNIT
 - EARTH BAR
 - DISTRIBUTION BOARD
 - MCCB PANEL BOARD
 - MECHANICAL CONTROL PANEL
 - 2 COMPARTMENT GALVANIZED TRUNKING DROPS FROM HIGH LEVEL TO SERVE DESK SMALL POWER AND DATA SERVICES
 - JUNCTION BOX MOUNTED WITHIN CEILING VOID - FIXED BASE CONNECTORS TO BE USED FOR FUTURE UPGRADE TO CORE B/C
 - JB
 - ATS
 - 'CV' DENOTES ITEM LOCATED WITHIN CEILING VOID
 - 'WP' DENOTES WEATHERPROOF ITEMS

9	15.01.21	REVISED TO SUITEA17,20,21 CAD	CAD
8	01.07.2020	STAGE 4 FINAL ISSUE	CAD
		INCORPORATING COMMENTS	
7	19.06.2020	REVISED TO SUIT NEW ARCHITECTS CA	CAD
6	15.05.2020	STAGE 4 ISSUE COMMENTS	CAD
5	07.05.2020	STAGE 4 ISSUE RECEPTION	CAD
4	07.04.2020	STAGE 4 DRAFT ISSUE	CAD
3	02.04.2020	STAGE 4 ISSUE	CAD
2	28.02.2020	DRAFT STAGE 4 ISSUE	CAD
1	13.12.19	STAGE 3 ISSUE	CAD
0	22.11.19	DRAFT STAGE 3 ISSUE	CAD
Rev	Date	Description	Drawn

Based on architect drawing

20BW-ALLP-ZZ-03-DR-A-2305-B

Issue status

STAGE 4

Project

UCL IOE, 20 BEDFORD WAY

PHASE 2

Title

LEVEL 3 CORE B

SMALL POWER & ANCILLARY

LAYOUT

Scale

1:500A0

Designed By


SN

Checked by

PEC

Date

NOV'19



building services consultants

long & partners

7110-20BW-

LP-CB-03-DR-E-3103

9

Copyright reserved. This drawing may not be used or reproduced without written consent. Dimensions should not be scaled from this drawing.