



**Key:**

- Existing combined drainage
- Existing drainage to be demolished
- Proposed surface water drain
- Proposed foul water drain

**Abbreviations:**

- CD - Channel drain
- Ex. - Existing
- FWP - Foul water pipe
- MH - Manhole
- RE - Rodding eye
- RWP - Rainwater pipe
- YG - Yard gully

**Notes:**

- Existing drainage shown as demolished is to be removed and replaced with clean fill material.
- Internal drainage within 300mm from underside of the slab is to be cast in concrete with reinforcement bars, Class Y bedding detail.
- External drainage with less than 600mm cover to be cast in concrete, Class Z bedding detail.
- Drainage cast in concrete is to be vitrified clay or u-PVC wrapped in miothene sheet. All other drains to be u-PVC. All proposed drains to be 100mm diameter.
- Existing drainage shown indicatively including branch pipework and manhole locations.
- Pipe bedding material around existing drain to be checked and reported to Engineer.

**PRICE &  
MYERS**