

<b>Application No:</b>	<b>Consultees Name:</b>	<b>Received:</b>	<b>Comment:</b>	<b>Response:</b>
2021/5599/P	MCAAC	04/01/2022 15:37:02	OBJ	The MCAAC appreciates the needs for secure cycle storage but is concerned that despite the note in the D&A statement, the height of this unit at 1.335 is excessive. Most cycles are below 1.000 tall even for a rider well over 1.800 metres tall. Allowing for fall and clearance and a roof thickness of 50mm, this should yield a maximum overall height of 1.150.

---