

SUPPORT STRUCTURE SCHEDULE										
EXISTING/ PROPOSED	OPERATOR	MANUFACTURER	MODEL	STRUCTURE HEIGHT	FOUNDATION TYPE (ROOT/PAD/GRILLAGE)	FOUNDATION DIMENSIONS (WxDxH)	COLOUR/ FINISH	STATUS	COMMENTS	
PROPOSED	TEF	-	-	3m	GRILLAGE	-	GALV.	NEW	3xTRIPOD	

FALL ARREST SYSTEM SCHEDULE										
EXISTING/ PROPOSED	OPERATOR	MANUFACTURER	MODEL	TYPE (HORIZONTAL/VERTICAL)	LOCATION	QUANTITY	TEST DUE	STATUS	COMMENTS	
PROPOSED	TEF	METREEL	INVISRUNG	VERTICAL	MAIN POLE	3	-	NEW	-	
IN-FLIGHT	TEF	METREEL	FALLGUARD	VERTICAL	FIXED STEEL LADDER	1	-	NEW	-	

ENCLOSURE SCHEDULE									
EXISTING/ PROPOSED	OPERATOR	MANUFACTURER	MODEL	DIMENSIONS (WxDxH)	LOCATION	COLOUR/ FINISH	STATUS	COMMENTS	
PROPOSED	TEF	ELTEK	4TH GEN OUTDOOR PSU	770x790x1940	STEEL GRILLAGE	GREY	NEW	-	
PROPOSED	TEF	NOKIA	FLATPACK FRAME	750x600x2000	STEEL GRILLAGE	GREY	NEW	GU09, L08/L09 & L18/L21	
PROPOSED	TEF	NOKIA	FLATPACK FRAME	750x600x2000	STEEL GRILLAGE	GREY	NEW	T23 & NR34	

RF EQUIPMENT SCHEDULE										
EXISTING/ PROPOSED	OPERATOR	MANUFACTURER	MODEL	DIMENSIONS (WxDxH)	LOCATION	QUANTITY	COLOUR/ FINISH	STATUS	COMMENTS	
PROPOSED	TEF	NOKIA	AIRSCALE 4G BBU	354.8x448x605	ELTEK PSU	1	GREY	NEW	GU09, L08/L09, L18/L21 & T23	
PROPOSED	TEF	NOKIA	AIRSCALE 5G BBU	354.8x448x605	ELTEK PSU	1	GREY	NEW	NR34	
PROPOSED	TEF	NOKIA	FXDB	535x324x260	RRU RAIL	3	GREY	NEW	U09	
PROPOSED	TEF	NOKIA	FXDB	447x133x420	FLATPACK FRAME 1	1	GREY	NEW	G09	
PROPOSED	TEF	NOKIA	FSMF	447x133x420	FLATPACK FRAME 1	1	GREY	NEW	G09	
PROPOSED	TEF	NOKIA	FRMF	535x324x260	RRU RAIL	3	GREY	NEW	L08	
PROPOSED	TEF	NOKIA	AHPMDA	512x330x130	UNISTRUT FRAME	3	GREY	NEW	L08/L09	
PROPOSED	TEF	NOKIA	AHEGB	560x308x149	RRU RAIL	3	GREY	NEW	L18/L21	
PROPOSED	TEF	NOKIA	AZNC	385x395x164	RRU RAIL	3	GREY	NEW	T23	
PROPOSED	TEF	NOKIA	AZQL	385x395x170	RRU RAIL	3	GREY	NEW	NR34	
PROPOSED	TEF	-	C2 COMBINER	328x131x263	ANTENNA SUPPORT POLE	6	GREY	NEW	L08/L09	
PROPOSED	TEF	-	C2 COMBINER	328x131x263	ANTENNA SUPPORT POLE	3	GREY	NEW	L09	
PROPOSED	TEF	-	GPS ANTENNA	95mmØ x 72.5	42U FLATPACK FRAME	1	-	NEW	REQUIRED GPS MODULE CABLE LENGTH 5m	

AC POWER SUPPLY SCHEDULE									
EXISTING/ PROPOSED	OPERATOR	MANUFACTURER	MODEL	SUPPLY TYPE (DNO/LL)	PHASE (SINGLE/THREE)	SUPPLY RATING (AMPS)	EARTHING (TN-C-S/TT)	COMMENTS	
PROPOSED	TEF	-	-	LL	THREE	100A	TT	EXISTING AC DB TO BE UPGRADE	


DC POWER SUPPLY UNIT SCHEDULE										
EXISTING/ PROPOSED	OPERATOR	MANUFACTURER	MODEL	LOCATION	AC SUPPLY TO PSU BREAKER SIZE (AMPS)	RECTIFIER SIZE (kW)	RECTIFIER QUANTITY	UPGRADE REQUIRED (Y/N)	COMMENTS	
PROPOSED	TEF	ELTEK	PSU	STEEL GRILLAGE	3x32A	3KW	5	N	ELTEK MK4 OUTDOOR PSU REQUIRED	

TRANSMISSION SUPPLY SCHEDULE									
EXISTING/ PROPOSED (ENCLOSURE)	OPERATOR		TRANSMISSION ENCLOSURE	TRANSMISSION SOLUTION (MICROWAVE ONLY/FIBRE ONLY/ MICROWAVE+FIBRE (WITH PROVIDER NAME))	U SPACE AVAILABLE	CURRENT TRANSMISSION EQUIPMENT LOCATION	PROPOSED TRANSMISSION EQUIPMENT LOCATION	COMMENTS	
	HOST	SHARER							
PROPOSED	TEF	-	ELTEK	FIBRE ONLY (BT)	15U	-	X	-	

ALL DIMENSIONS ARE IN mm UNLESS NOTED OTHERWISE			
N.G.R	E: 530014	N: 181123	
CONCESSION REQUIRED		YES	
DESIGN DEPENDENCIES			COMPLETED
STAT SEARCH RESULTS	NO	XX.XX.XXXX	
ASBESTOS REPORT	✓	09.07.19	
RADAR SCAN REPORT	NO	XX.XX.XXXX	
COOLING CALCS	NO	XX.XX.XXXX	
LL FIRE ALARM ASSESS	✓	-	
GDC LEVEL	1	NO	XX.XX.XXXX
STRUCTURAL CALCS	✓	-	
HD BOLT GRADE TEST	NO	XX.XX.XXXX	
FOUNDATION CALCS	NO	XX.XX.XXXX	
BOREHOLE REPORT	NO	XX.XX.XXXX	
TRIAL HOLE REPORT	NO	XX.XX.XXXX	
BOLT PULL TEST	NO	XX.XX.XXXX	
BUILDING REG'S APP.	NO	XX.XX.XXXX	
NET RAIL TECH PACK	NO	XX.XX.XXXX	
DNO QUOTE APPROVAL	NO	XX.XX.XXXX	
ELECTRICAL CALCS	✓	-	

REFER TO THE SITE SPECIFIC DRAWING SUBMISSION CHECKLIST (SDN0020) FOR A COMPREHENSIVE LIST AND INSTRUCTION ON WHERE TO FIND ALL ACCOMPANYING DESIGN DOCUMENTATION.

A	Issued for Approval	SBL	RA	21.07.21
REV	MODIFICATION	BY	CH	DATE



Cell Name	Opt.
164 SHAFTSBURY AVENUE	-

Cell ID No		
CORNERSTONE	TEF	VF
235679_20	80187	N/A

Site Address / Contact Details

164 SHAFTSBURY  
164 SHAFTSBURY AVENUE  
LONDON  
GREATER LONDON  
WC2H 8HL

Drawing Title: EQUIPMENT SCHEDULE			
Purpose of issue: PLANNING			Dwg Rev:
Drawing Number: 502			A
Surveyed By: RA		Original Sheet Size: A3	Pack Issue:
Drawn: SBL	Date: 12.07.21	Checked: RA	Date: 21.07.21
			A