

- 1. This drawing is to be read in conjunction with all relevant Architect's, Engineer's and specialists' drawings and specifications.
- Do not scale from this drawing in either paper or digital form. Use written dimensions only. All dimensions are in millimetres and levels in metres. To check that this drawing has been printed to the intended scale this bar should be 50mm long @A1 or 25mm long @ A3
- Health & Safety: All specific drawing notes are to be read in conjunction with the project "Information Pack" and "Site Rules".
- 4. For general notes refer to Drawing No. AGV-PAM-SW-XX-DR-S-000001
- 5. For details of the ground conditions refer to report by PBA Ref 28732/006/002 April 2014.
- 6. The piling scheme is based on an assumed maximum compressive load of 850kN for a 350mm dia CFA pile.
- 7. Final design of all piles is by the specialist piling contractor.
- 8. Loads given exclude self-weight of piles. Anchorage of the piles in the pile caps/ground beams to be designed by the piling contractor.
- 9. Concrete piles to be FND3
- 10. UXO Management strategy required for intrusive works.
- 11. All piles to be integrity tested
- 12. Pile design to Eurocode 7 and the UK national annex.
- 13. Existing pile locations as per survey drg no.1408/01 received on 21/06/2021 by Mark Beaver Surveying
- 14. All existing piles are 200mm diameter with exclusion zone 400mm from edge of piles, as recommended by Van Elle
- 15. Proposed piles are postioned outside the exclusion zone, however the inclination of existing piles is not known.
- 16. Engineer to be advised if piles are unable to be installed
- as required. This may require multiple additional piles 17. Where noted, *1*, *2*, *3*... piles to be installed in
- sequence around existing piles
- 18. Existing piles to be broken down minimum 1m below underside of proposed structure

C03	30.07.21	JEM	LK	P229 installed out of place as clouded. Crane base pile sizes increased
C02	12.07.21	JEM	LK	Revised as clouded
C01	06.07.21	JEM	LK	Issued for Construction
P02	22.03.21	JEM	LK	Issued for Information
P01	04.03.21	JEM	LK	Issued for Information
Rev	Date	Drawn	Eng	Amendment

AGAR GROVE PHASE 1C. BLOCKS JKL

PILE LAYOUT SHEET 2

FOR CONSTRUCTION

Drawn	JEM	Eng	SW	
Scales	1:100 at A1	1:200	at A3	
Drawing	No			Rev

29333/ BLKJKL-001081 C03

AGV-PAM-JKL-B2-DR-S-001081



Consulting Engineers 37 Alfred Place London WC1E 7DP 020 7631 5128 mail@pricemyers.com www.pricemyers.com