

CONSULTANTS' ADVICE NOTE

Arthur Stanley House Smoke Extract System Fire Statement

1 INTRODUCTION

1.1 Intent

This Consultants' Advice Note (CAN) has been produced to provide the fire safety justification for a minor application for planning regarding the provision of fire safety equipment that is essential for a smoke ventilation system for Arthur Stanley House in London.

Previous planning permission (ref. 2017/4306/P as amended) was approved in 2018 in the intervening years the fire industry has been responding to more onerous fire safety requirements imposed by key stakeholders including the London Fire Brigade. Within the consented scheme at the site, an AOV was situated at the head of the main commercial stair. However, after a long design process and delayed LFB submission / review (due to COVID-19), the fire safety ventilation system within the main stair was subjected to more onerous requirements and focus.

This CAN is to highlight the reasoning why this system was introduced at a late stage of design.

1.2 Change in Requirements

Upon review of the more onerous requirements on fire safety, the previously suitable solution in the early stages of design was re-evaluated against more stringent acceptance criteria.

To meet the more onerous requirements of the LFB and Building Control Body peer review process, the AOV at the head of the main stair was replaced with a mechanical fan set that will form a vital part of the life safety (smoke ventilation) system in a fire. Without this fan set, LFB and Building Control approval would not be obtainable, and the building could not be occupied. Alternative solutions were explored; however, these alternative solutions were not feasible due to a variety of constraints such as clashes with existing structure, technical system restrictions on pressure differences and substantial smoke shaft size increases that are not possible due to clashes with other services.

1.3 Conclusion

The following are concluded with respect to the requirement for the proposed second fan set:

- This system is necessary for the fire safety design of the building and forms an essential part of the LFB and BCB approvals process.

- The system will only be active in the event of a fire within the building, or during testing, and therefore the duration of exposure to noise generated by the fan sets and frequency of exposure is limited to testing and emergency only.

QUALITY CONTROL

Document Reference No: AFF_20169_02_Arthur Stanley House_Smoke Ventilation_CAN_02

Rev	Date Issued	Comment	Prepared by	Reviewed by	Verified by
01	07/01/22	Issue for Planning	Ids Van der Wal BEng (Hons), MSc AIFireE	Roderic Jones MEng (Hons), CEng MIFireE	Roderic Jones MEng (Hons), CEng MIFireE
02	10/01/22	Update based on DP9 comments	Ids Van der Wal BEng (Hons), MSc AIFireE	Roderic Jones MEng (Hons), CEng MIFireE	Roderic Jones MEng (Hons), CEng MIFireE

Affinity Fire Engineering UK Ltd

120 Aldersgate Street, London, EC1A 4JQ

+44 (0) 20 3384 0050, enquiries@affinity-fire.com

Copyright ©

All rights reserved. No part of this document may be reproduced, published, transmitted or adapted in any form or by any means without the written permission of Affinity Fire Engineering (UK) Ltd.

Disclaimer

The information contained in this document is provided for the sole use of the named **client and** applies only to the named project. No reliance should be placed on the information by any other person or for any other project. In the event that the information is disclosed or furnished to any other person, or applied for any other project, Affinity Fire Engineering (UK) Ltd accepts no liability for any loss or damage incurred by that person whatsoever as a result of using the information.