

- KEY**
- KITCHEN/ STORE / STAFF BOH
 - LIQUOR STORE
 - PUBLIC OPEN SPACE
 - CUSTOMER WCL & PASSAGEWAYS
 - DRINKING/ EATING AREAS

Seating layout and location of fire safety equipment indicative only.

EMERGENCY LIGHTING SYSTEM
An independent self-contained non-maintained system, type XDA100, will be installed in accordance with BS 5266-1:2011, Emergency Lighting - Part 1: Code of Practice for Emergency Lighting of premises other than cinemas and certain other specified premises for entertainment, and BS EN 9012: 2004, BS 5266-4: 2004 Lighting Applications - Emergency Lighting. Luminaires will be located in the approximate positions indicated on this drawing. All signs and notices will comply with BS 5489 - Part 1 - Fire Safety Notices and Graphic Symbols.

- 3 hr maintained exit legend
- 3 hr non-maintained Channel Marker's office Bulbhead
- Fire fighting equipment


FIRE ALARM SYSTEM
A Fire Alarm system will be installed to BS 5839 - Part 1, 2013 Code of Practice for system design, installation, commissioning and maintenance, comprising of devices as indicated, in non-domestic premises. The system category is to be an L2 system.

- Fire Alarm Panel
- Manual Call Point
- Heat Detector
- Smoke Detector
- Indicator For Vaid detector
- Indicator Vaid detector
- Sounder/Sounder Base

- EXTINGUISHERS
- CO2
- FOAM
- CHEMICAL

1 Proposed Plan
Scale: 1:200 @A3

DISABLED ALARM SCHEMATIC & SETTING OUT



Notes

NOTE: THE CURRENT LOCATION OF FIRE SAFETY EQUIPMENT AND OTHER SAFETY EQUIPMENT IS SHOWN. THESE MAY BE SUBJECT TO VARIATION IN THE FUTURE AS NECESSARY AND WHERE APPLICABLE IN LIAISON WITH THE FIRE OFFICER.

S1 15/12/2021 Draft licensing plan

Project

Hawley Wharf Rooftop 1

Client

Corrigan Collection

Drawing Title

Restaurant A1
Licensing Plan

Scale Date Created
1:200 @ A3 14/12/2021

Drawing Number
14590-800

Revision Revision Date
S1 15.12.21

Drawn By Checked By
OB MS

Do not scale from drawing, all dimensions to be checked on site. Report omissions and discrepancies to the architect immediately.



Michaelis Boyd Associates
108 Palace Gardens Terrace
London W8 4RT

44 207 221 1237
hello@michaelisboyd.com
michaelisboyd.com