



LEGEND	
TYPE	DESCRIPTION
 DL7	Recessed downlight with wide beam, warm white
 DL7E	Recessed maintained emergency downlight with wide beam, warm white, supplied with 3hr emergency pack

Date	Rev	Description
21/05/21	C2	Lighting aligned with Permasteelisa structure
23/03/21	E	Draft for Co-ordination
04/09/20	D	North arrow and scale bar added for planning
17/07/20	C1	Updated notes
03/07/20	C	L5 removed; setting out added; legend and annotation updated
29/05/20	B	Downlights added
09/11/18	A	Generally updated following comment from MBA
12/07/18	DFT	First Issue DRAFT

Notes

All emergency lighting in this area is DALI reporting and forms part of the Lutron system for monitoring

Final co-ordination of luminaires required with facade contractor

DALI drivers for luminaires are remote and are to be housed in the ceiling void adjacent to fitting. Maximum driver distances and dimensions can be found in the luminaire specification.

Emergency battery packs fit through downlight cut-out and are to be placed in the ceiling void adjacent to the downlight.

Emergency indicators are remote and are to be located in the ceiling adjacent to the emergency downlight

Important Note

Where Dimensions are not given, drawings must not be scaled.

For complete luminaire breakdown refer to schedules

In the event of conflict between this drawing and lead consultants drawing the matter must be referred prior to proceeding

CLIENT	Lazari Investments Ltd	
PROJECT	Stephenson House, 75 Hampstead Road, London, NW1 2PL	PROJECT NO. 0164
STATUS	For Construction	
SCALE	1:25 @ A1 1:50 @ A3	DATE 12/07/2018
TITLE	SME Entrances First Floor Exterior RCP	
DRAWING NO.	0164 - 203	REVISION C2

