



**156 West End Lane, West Hampstead
Planning Conditions 21 & 22**

14 March 2022

Air Source Heat Pump (ASHP) & Gas Boiler details

Inspiring Built
Environments

MEP
Sustainability
Building Physics

	Description	Prepared by	Reviewed by	Authorised by	Date
01	Draft issue for comment	Nathan Town	Kirk Buxton	James Taylor	04/11/21
02	Incorporates manufacturers Energy Calculations	Nathan Town	Kirk Buxton	James Taylor	09/11/21
03	Comments incorporated	Nathan Town	David Porter	James Taylor	03/12/21
04	Comments incorporated	James Taylor	Kirk Buxton	James Taylor	14/03/22

Audit Sheet

This document has been prepared for Astir only and solely for the purposes expressly defined herein. We owe no duty of care to any third parties in respect of its content. Therefore, unless expressly agreed by us in signed writing, we hereby exclude all liability to third parties, including liability for negligence, save only for liabilities that cannot be so excluded by operation of applicable law. The consequences of climate change and the effects of future changes in climatic conditions cannot be accurately predicted. This report has been based solely on the specific design assumptions and criteria stated herein.

Contents

Audit Sheet1

Introduction.....3

 Purpose of this report and overview of supplied information3

 Overview of the ASHP/Gas boiler strategy.....3

Appendix A – ASHP & Gas Boiler Information5

Appendix B – CO² emissions7

Appendix C – Gas Boiler Flue Requirements and Location Details.....8

Introduction

Purpose of this report and overview of supplied information

The approved regeneration of 156 West End Lane (2019/4140/P) comprises 180 mixed tenure residential dwellings (use Class C3), flexible non-residential use (Class A1-A3, D1, D2), employment floorspace (Use Class B1) and community space (Use Class D1) in buildings ranging from 3 to 7 storeys. New vehicular access from West End Lane and the provision of accessible car parking spaces, in addition to new public open space, the widening of Potteries Path and associated cycle parking and landscaping.

The original parent permission (2015/6455/P) was approved on 23rd June 2017 and two pre-commencement planning conditions (Conditions 21 and 22), dealing with the details of the combined heat and power unit (CHP), emission standards and the air inlets were discharged in March 2020 (2019/6364/P).

In advance of a construction start on site, a detailed technical design review of the approved schemes has been undertaken by the applicant, Astir Living. A key element has focused on the approved energy scheme and the changes in both policy and direction that have taken place in energy and sustainability practices since the application was first approved in 2017.

The new London Plan (2021) recognises that the carbon savings from gas engine CHP are now declining as a result of national grid electricity decarbonising, and there is increasing evidence of adverse air quality impacts (paragraph 9.3.3). Therefore, FHP has been working on improving the approved Energy Strategy (also submitted with this application) and now propose the use of more efficient Air Source Heat Pumps (ASHP) with a supplementary gas boiler to provide the heating and hot water production to the development. The ASHP and gas boiler will be located within the approved plant room, in the lower ground floor of the East building.

It is proposed that the wording of the relevant conditions within planning permission 2019/4140/P will be amended via an application made under S73 of the Town and Country Planning Act and this report has been prepared as the detail to discharge Conditions 21 and 22 in this respect.

This report provides the following information:

Appendix A:

- Manufacturers information on the proposed ASHP units: 5 No. Mitsubishi Electric CAHV-P500YB-HPB have been selected.
- Manufacturers information on the proposed gas boilers: 1 No. Hoval Ultragas 600D has been selected.

Appendix B:

- Manufacturers information on the ASHP and gas boilers highlighting the energy usage and how they meet the Mayor's Sustainable Design and Construction SPG (Condition 21).

Appendix C:

- Gas boiler flue route and location relative to air-inlet locations (Condition 22).

Overview of the ASHP/Gas boiler strategy

FHP has prepared an Energy Strategy (0001-L-FHP-DES-058-0001 Rev-P7 March 22) to support the proposals for the change from CHP to ASHP. When compared to the regulatory baseline scenario as set out in the GLA guidance and Part L 2012, the Energy Strategy concludes that the use of ASHP's alongside the supplementary gas boilers, and PVs on the roofs of both buildings reduce carbon emissions by 59% in the case of residential dwellings, and 43% in the case of non-residential areas.

The proposed ASHP units: 5 No. “Mitsubishi Electric CAHV-P500YB-HPB” (Please refer to Appendix A) will produce 40kWt thermal (each). The emissions produced from these units is less than that stated in Mayor’s Sustainable Design and Construction SPG (Please refer to Appendix B – Section 4.0 Primary Energy Comparison).

The proposed gas boilers: 1 No. “Hoval Ultragas 600D” (Please refer to Appendix A) will produce 603kWt thermal (each). The emissions produced from this unit is less than that stated in Mayor’s Sustainable Design and Construction SPG (Please refer to Appendix B).

The ASHP units will be located within within the approved plant room at lower ground floor level within the east building (Please refer to Appendix C).

The gas boiler will be located in the within the approved plant room at lower ground floor level within the east building (Please refer to Appendix C) and the flue associated with this unit will discharge at roof level of the third floor in the east building (link building). The flue will discharge between 1.5m and 2.5m above roof level (depending on a detailed flue design by a flue specialist) There are no air inlets located on the roof, eliminating the risk of the flue gasses contaminating any ventilation intakes.

Appendix A – ASHP & Gas Boiler Information

PROJECT NO. 11410
PROJECT NAME - 156 West End Lane
DOCUMENT REF - 0001-M-FHP-PL-011-0001
SCHEDULE - BOILER SCHEDULE
REVISION - P02 | ISSUE DATE - 12.05.2021 | BY/CHECK - NT/BD



BOILER SCHEDULE

REFERENCE	BLR
No OF	01
MANUFACTURER/MODEL	Hoval Ultragas 600D
TYPE	Floor Mounted Modular
LOCATION	East Block Basement Boiler
HEATING CAPACITY (kW) @ 80/60)	603
WATER CONTENT (L)	529
DESIGN WATER OULET TEMP. (°C)	65
DESIGN WATER RETURN TEMP. (°C)	56
PRESSURE DROP (mbar)	10
% EFFICIENCY (SEASONAL GROSS)	98.3
FUEL	Natural Gas
GAS FLOW RATE (kW)	614
MINIMUM GAS PRESSURE (MBAR)	17.4
WEIGHT - DRY (KG)	1303
ELECTRICAL DETAILS	
VOLTS/PHASE/HERTZ	230V/1/50Hz
POWER (W)	1030
DIMENSIONS	
HEIGHT	1923
WIDTH	1880
DEPTH	1790
COMMENT	600D Boiler comes in transit as 2 boiler and is then Joined.

PROJECT NO. 11410
PROJECT NAME - 156 West End Lane
DOCUMENT REF - 0001-M-FHP-PL-011-0005
SCHEDULE - ASHP SCHEDULE
REVISION - P02 | ISSUE DATE - 12.05.2021 | BY/CHECK - NT/BD



ASHP SCHEDULE

REFERENCE	ASHP
No OF	5
MANUFACTURER/MODEL	Mitsubishi Electric / CAHV-P500YB-HPB
TYPE	ASHP
LOCATION	East Block
HEATING CAPACITY (kW)	40
SPACE HEATING FLOW RATE (L/s)	2.1
TEMPERATURE FLOW & RETURN (°C) Summer	51-30
TEMPERATURE FLOW & RETURN (°C) Winter	56-35
PRESSURE DROP (kPa)	20.4
DIMENSIONS (mm)	1979mm(w) X 159mm (d) X 1650mm (H)
WEIGHT - DRY (KG)	526
SEASONAL COP	2.94 Minimum
ELECTRICAL DETAILS	
VOLTS/PHASE/HERTZ	230V/1/50Hz
MAX RUNNING CURRENT (AMPS)	52.9

Appendix B – CO² emissions

Heat Pump Sizing Assessment

Project Ref SAV/HP/114544/RS(MD)/09 Nov 2021
Project Name West End Lane 156 (Rev 5)
Proposal 5no CAHV 43kW Heat Pump + Gas Boiler
Assessor Megan De Nysschen



Headlines

Source of emission factors:

SAP 10.1

Project Region:

1 Thames

Annual Heat Demand

746,039 kWh

Site Temperatures

Flow: 60°C

Return: 30°C


Heat Pump

Max Outlet Temperature

51°C


COP & SCOP

SCOP = 3.1




Heat Pump Share

70%



Carbon Footprint (kg/CO₂)


-54%



Comparison with Notional Building


Primary Energy kWh

-40%



Operating Cost (£)

+39%



* Notional building with gas boiler

Report

NOTE: This assessment is specific to the CAHV Heat Pump only - As supplied by SAV Systems

Number of 43 kW CAHV heat pumps	5
Minimum HP Thermal Store Capacity	2000 litres
Type of Building	Multi-residential & Mixed Commercial
Data reference	BRUKL & SAP data from FHP Energy Strategy - Appendices dated October 2021 Ref 0001-L-FHP-DES-058-0001 Rev 4-P4. Data taken from 'Be Green' iterations of BRUKL & SAP

1.0 Summary of Usage:


Annual heat demand	746,039 kWh	See Appendix Table 1
Site flow temperature	60°C	
Site return temperature	30°C	
Heat pump flow temperature	51°C	
Gas tariff	3.87 p/kWh	As PCDB Fuel prices (From January 2021)
Electricity tariff	18.9 p/kWh	As PCDB Fuel prices (From January 2021)

1.1 CO₂ Emission Factors used:

Source of emission factors used	SAP 10.1
CO ₂ Emission Factor for Gas	0.210 kg CO ₂ /kWh
CO ₂ Emission factor for Grid Electricity	0.146 kg CO ₂ /kWh

2.0 Carbon Footprint Comparison:


Notional Building (Gas Boiler)	159,378 kg CO ₂ pa (See Appendix Table 6)
Heat Pump Solution	72,529 kg CO ₂ pa (See Appendix Table 3)
Reduction	86,849 kg CO ₂ pa



Carbon reduction due to proposed Heat Pump:	87 tonnes (compared with notional building) 86,849 / 159,378 = 54% reduction
---	---

3.0 Energy Cost Comparison:

Notional Building (Gas Boiler)	£29,371 (See Appendix Table 6)
Heat Pump Solution	£40,868 (See Appendix Table 4)
Increase	£11,497




Energy cost increase due to proposed Heat Pump:

£11,497 (compared with notional building)
 $£11,497 / £29,371 = 39\%$ increase

4.0 Primary Energy Comparison:

Notional Building (Gas Boiler)	857,603 kWh pa (See Appendix Table 6)
Heat Pump Solution	518,307 kWh pa (See Appendix Table 5)
Reduction	339,297 kWh pa




Primary Energy reduction due to proposed Heat Pump:

339,297 kWh (compared with notional building)
 $339,297 / 857,603 = 40\%$ reduction

5.0 Heat Pump Share Of Heat

Building Heat Demand	746,039 kWh pa
Heat Pump Output	522,227 kWh pa (See Appendix Table 2)
Boiler Heat Output	223,812 kWh pa (See Appendix Table 2)
Heat Pump Share	70.0%
Boiler Heat Share	30.0%




6.0 Seasonal Coefficient of Performance - SCOP

Heat Pump SCOP	3.08 See Appendix Table 2
----------------	------------------------------

COP = Instantaneous
= Power In / Power Out

SCOP* = Seasonal
= Energy In / Energy Out

* or SPF - Seasonal Performance Factor



7.0 Appendix

TABLE 1 - Heating & DHW Demands

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Project Space Heating Demand	kWh	35,218	31,086	32,754	29,510	29,027	26,091	25,204	27,454	27,343	30,593	32,163	34,420	360,864
Project DHW Demand	kWh	62,765	46,251	34,787	15,875	4,892	24,375	22,587	25,919	26,228	15,980	40,809	64,707	385,175
Total Heat Demand	kWh	97,983	77,338	67,541	45,385	33,919	50,465	47,791	53,373	53,571	46,573	72,972	99,127	746,039

TABLE 2 - Heat Pump / Boiler Share

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Project Heat Demand	kWh	97,983	77,338	67,541	45,385	33,919	50,465	47,791	53,373	53,571	46,573	72,972	99,127	746,039
Heat Pump Heat Output	kWh	68,588	54,136	47,279	31,770	23,743	35,326	33,453	37,361	37,500	32,601	51,081	69,389	522,227
COP		2.71	2.71	2.91	3.13	3.30	3.65	3.80	3.77	3.58	3.27	3.00	2.79	3.08
Heat Pump Energy Input (Electric)	kWh	25,300	19,967	16,274	10,149	7,184	9,683	8,806	9,914	10,478	9,957	17,020	24,877	169,611
Supplementary Boiler Heat Output	kWh	29,395	23,201	20,262	13,616	10,176	15,140	14,337	16,012	16,071	13,972	21,892	29,738	223,812
Boiler Efficiency		98%	98%	98%	98%	98%	98%	98%	98%	98%	98%	98%	98%	
Boiler Energy Input (Gas)	kWh	29,903	23,603	20,613	13,851	10,352	15,401	14,585	16,289	16,349	14,214	22,270	30,252	227,682
Share Of Heat From Heat Pump		70%	70%	70%	70%	70%	70%	70%	70%	70%	70%	70%	70%	70%
Share Of Heat From Boiler		30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%

TABLE 3 - CO₂ Calculations

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Heat Pump Energy Input (Electric)	kWh	25,300	19,967	16,274	10,149	7,184	9,683	8,806	9,914	10,478	9,957	17,020	24,877	169,611
CO ₂ Factor	Electric	0.163	0.160	0.153	0.143	0.132	0.120	0.111	0.112	0.122	0.136	0.151	0.163	0.146
Carbon Emission for Heat Pump	kg CO ₂	4,124	3,195	2,490	1,451	948	1,162	978	1,110	1,278	1,354	2,570	4,055	24,716
Boiler Energy Input (Gas)	kWh	29,903	23,603	20,613	13,851	10,352	15,401	14,585	16,289	16,349	14,214	22,270	30,252	227,682
CO ₂ Factor	Gas	0.210	0.210	0.210	0.210	0.210	0.210	0.210	0.210	0.210	0.210	0.210	0.210	0.210
Carbon Emission for Gas Boilers	kg CO ₂	6,280	4,957	4,329	2,909	2,174	3,234	3,063	3,421	3,433	2,985	4,677	6,353	47,813
Carbon Emission for Proposal	kg CO ₂	10,404	8,151	6,819	4,360	3,122	4,396	4,040	4,531	4,712	4,339	7,247	10,408	72,529

TABLE 4 - Energy Cost Calculations

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Heat Pump Energy Input (Electric)	kWh	25,300	19,967	16,274	10,149	7,184	9,683	8,806	9,914	10,478	9,957	17,020	24,877	169,611
Fuel Tariff for Heat Pump	Electric p/kWh	18.90	18.90	18.90	18.90	18.90	18.90	18.90	18.90	18.90	18.90	18.90	18.90	18.90
Heat Pump Energy Cost		£4,782	£3,774	£3,076	£1,918	£1,358	£1,830	£1,664	£1,874	£1,980	£1,882	£3,217	£4,702	£32,057
Boiler Energy Input (Gas)	kWh	29,903	23,603	20,613	13,851	10,352	15,401	14,585	16,289	16,349	14,214	22,270	30,252	227,682
Fuel Tariff for Boiler	Gas p/kWh	3.87	3.87	3.87	3.87	3.87	3.87	3.87	3.87	3.87	3.87	3.87	3.87	3.87
Boiler Energy Cost		£1,157	£913	£798	£536	£401	£596	£564	£630	£633	£550	£862	£1,171	£8,811
Energy Cost for Proposal		£5,939	£4,687	£3,873	£2,454	£1,758	£2,426	£2,229	£2,504	£2,613	£2,432	£4,079	£5,873	£40,868

TABLE 5 - Primary Energy Calculations

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Heat Pump Energy Input (Electric)	kWh	25,300	19,967	16,274	10,149	7,184	9,683	8,806	9,914	10,478	9,957	17,020	24,877	169,611
Primary Energy Factor	Electric	1.602	1.593	1.568	1.530	1.487	1.441	1.410	1.413	1.449	1.504	1.558	1.604	1.539
Primary Energy Input for Heat Pump	kWh	40,531	31,807	25,517	15,528	10,683	13,953	12,417	14,009	15,183	14,976	26,518	39,903	261,026
Boiler Energy Input (Gas)	kWh	29,903	23,603	20,613	13,851	10,352	15,401	14,585	16,289	16,349	14,214	22,270	30,252	227,682
Primary Energy Factor	Gas	1.130	1.130	1.130	1.130	1.130	1.130	1.130	1.130	1.130	1.130	1.130	1.130	1.130
Primary Energy Input for Gas Boilers	kWh	33,791	26,671	23,293	15,652	11,697	17,404	16,481	18,406	18,475	16,061	25,165	34,185	257,281
Primary Energy for Proposal	kWh	74,322	58,478	48,810	31,180	22,381	31,356	28,898	32,415	33,657	31,037	51,683	74,089	518,307

TABLE 6 - Notional Building

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Boiler Heat Output	kWh	97,983	77,338	67,541	45,385	33,919	50,465	47,791	53,373	53,571	46,573	72,972	99,127	746,039
Boiler Efficiency		98%	98%	98%	98%	98%	98%	98%	98%	98%	98%	98%	98%	
Boiler Energy Input	Gas kWh	99,678	78,675	68,710	46,170	34,506	51,338	48,617	54,296	54,497	47,379	74,234	100,841	758,941
CO ₂ Factor	Gas	0.210	0.210	0.210	0.210	0.210	0.210	0.210	0.210	0.210	0.210	0.210	0.210	0.210
Carbon Emission for Boilers	kg CO ₂	20,932	16,522	14,429	9,696	7,246	10,781	10,210	11,402	11,444	9,950	15,589	21,177	159,378
Fuel Tariff for Boiler	Gas p/kWh	3.87	3.87	3.87	3.87	3.87	3.87	3.87	3.87	3.87	3.87	3.87	3.87	3.87
Boiler Energy Cost		£3,858	£3,045	£2,659	£1,787	£1,335	£1,987	£1,881	£2,101	£2,109	£1,834	£2,873	£3,903	£29,371
Primary Energy Factor	Gas	1.130	1.130	1.130	1.130	1.130	1.130	1.130	1.130	1.130	1.130	1.130	1.130	1.13
Primary Energy Input for Boilers	kWh	112,636	88,903	77,642	52,172	38,992	58,012	54,937	61,355	61,582	53,538	83,885	113,951	857,603

8.0 References

Total DHW													
Quantity	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total DHW
180	35,217.96	31,086.47	32,754.48	29,510.31	29,026.69	26,090.77	25,204.05	27,454.48	27,342.78	30,593.29	32,162.94	34,420.27	360,864.48
Total Heating													
Quantity	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total DHW
180	62,765.39	46,251.14	34,786.98	15,874.90	4,892.49	0.00	0.00	0.00	0.00	15,980.04	40,809.23	64,706.61	286,066.78

Appendix C – Gas Boiler Flue Requirements and Location Details

Lower Ground East Block Plantroom Location:

This drawing is based on:
0001-A-CTA-M03-01-00-5500
0001-L-FAB-M03-ZZ-ZZ-0001
0001-S-IES-M03-00-XX-5500

This drawing is to be read in conjunction with all related consultants drawings and any other relevant information.
This drawing is the copyright of FHPP Ltd.

Do not scale from this drawing. All dimension in millimetres unless otherwise stated.
All dimensions to be verified on site prior to the commencement of any work or the production of any shop drawing. All discrepancies to be reported to FHPP Ltd immediately.

General Mechanical Notes

- The drawings are to be read in conjunction with all other accompanying FHP drawings, schedules & specification documents.
- All dimensions in millimetres unless otherwise noted.
- The drawings are not to be scaled from.
- All routes are to be checked on site prior to the commencement of works.
- All pipework, ductwork & plant to be installed in accordance with the manufacturer's recommendations and guidelines.
- All services routes are to be agreed between the design team and client prior to installation and to be checked on site prior to the commencement of works.

5x ASHP c/w 760mm x 750mm
Fresh Air & Exhaust Ductwork
1500(L) x 750(H) x 750(W) Attenuators

All external Heating Pipework shall
be trace heated and insulated

350mmØ Boiler Flue at HL

100mmØ LTHW R at LL

125mmØ Incoming Gas Supply MDPE

Pumps installed on wall in vertical

2x 2500 Litre Vessels

100mmØ LTHW F + R at HL

100mmØ LTHW F + R at HL

100mmØ LTHW F + R at HL

100mmØ LTHW F + R at HL

28mmØ LTHW F + R to serve Buffer Vessels
& Pressurisation

Floor Mounted horizontal pipework

100mmØ LTHW F + R at HL

65mmØ LTHW F+R to Below Ground

65e LTHW F

65e LTHW R

15mmØ Bib Tap

28mmØ CAT5 Pipework to Below Ground

28mmØ CAT5 Pipework drops to
CAT 5 Tank

108mmØ BCWS Pipework drops to
CAT 5 Tank

Electrical BMS Panel (BMS)

Mechanical Control Panel (MCCP)

80e LTHW F

80e LTHW R

108mmØ BCWS Pipework at HL

28mmØ CAT5 Pipework at HL

80mmØ LTHW F+R Pipework at HL to serve Plant Room

108mmØ BCWS Pipework from underground Storage
Tank enters Plant Room at HL

32mmØ LTHW F+R & 28mmØ BCWS Pipework at HL to serve Plant Room

ENERGY CENTRE & TANK ROOMS
SCALE: 1 : 50

Lightwell above
open to atmosphere


Louvered opening

Boiler
Plant

Boiler Flue travels up to
3rd floor roof level from
this point

28mmØ BCWS Pipework at HL
to Serve Apartment
20mmØ LTHW F+R & 28mmØ BCWS
Pipework at HL to serve Apartment
28mmØ CAT5 Pipework at HL
108mmØ BCWS Pipework at HL
80mmØ LTHW F+R Pipework at HL

65mmØ LTHW F+R Pipework drop to
Below ground see External Services Drawing.
60mmØ LTHW F+R Pipework Rise
to serve Floors Above
35mmØ BCWS Pipework to Meter to
serve Manifold
76mmØ BCWS Pipework from Below Ground Rises
to serve Floors Above
28mmØ CAT5 Supply Pipework drop to
Below Ground see External Services Drawing



P05	06/12/21	Plantroom Revised	KW	DP
P04	12/05/21	Stage 4 Issue	KW	BD / DC
P03	07/05/21	Stage 4 Issue	KW	BD / DC
P02	12/02/21	Generator added	CT	BD / DC
P01	13/11/20	Preliminary Issue	CT	BD / DC
Rev	Date	Description	Drm	Chck

Client
astir.

Job Title
West End Lane

FHP
1a Brewery Place, Brewery Wharf, Leeds, LS10 1NE
Tel: 01132350860 Email: admin@fhpp.com

Drawing Title
**Combined Services
Plantroom Co-ordination Layout**

Scale As indicated @ A1 FHP Job Number
11410

Stage 4 S2

Drawing Number
0001-B-FHP-DRG-25-ZZ-5502
Revision
P05

East Block Roof Level - Flue Termination:

Do not scale from this drawing. All dimension in millimetres unless otherwise stated.
All dimensions to be verified on site prior to the commencement of any work on the production of any shop drawing. All discrepancies to be reported to FHPP Ltd immediately.

General Notes:

- The drawings are to be read in conjunction with all other accompanying FHP drawings, schedules & specification documents.
- All dimensions in millimetres unless otherwise noted.
- The drawings are not to be scaled from.
- All routes are to be checked on site prior to the commencement of works.
- As per work, however, compliance is due to be installed in accordance with the manufacturer's recommendations and guidelines.
- All service routes are to be agreed between the design team and client prior to installation and to be checked on site prior to the commencement of works.

Heating Notes:

- The contractor shall make adequate provision for expansion bellows & loops with all associated brackets, gaskets & unions. Expansion bellows to be confirmed by manufacturer.
- All pipework to be sleeved & fire stopped to BS 476 (the minimum) where passing through fire separating boundaries. Sleeves to be flush with services where pipework exposed.
- Although not shown, include for A/V's at all high points & drain cocks at all low points on the system.
- All radiators to be fitted with TRVs & LST's.
- Radiator connections to be BSCE.
- All main plant shall be installed with isolating valves & unions.
- As prepared to be presented before prior to the application of insulation.
- For first valve arrangement refer to relevant service schematic.

Legend

Symbol	Description
	Demolish Pipework within Ceiling Void
	Isolation Valve
	Demolish change in level



P03	12/05/21	Stage 4 Issue	KW	BD
P02	12/03/21	Stage 4 Issue	CT	BD
P01	06/11/20	Preliminary Issue	CT	BD
Rev	Date	Description	Dm	Chk

Client

Job Title
West End Lane

1a Brewery Place, Brewery Wharf, Leeds, LS10 1NE
Tel: 01132350860 Email: admin@fhp.com

Drawing Title
East Block
Third Floor
Heating Services

Scale 1 : 100 @ A0	FHP Job Number 11410
--------------------	----------------------

Stage 4	S2
Drawing Number 0001-M-FHP-DRG-56-03-5501	Revision P03

