


Note: This view is to show approximate location of lighting fittings at site entrances on eastern facade. This view is indicative only.

Proposed Luminaire Details							
Symbol	Reference	Type	Colour Temperature	Mounting Type	Mounting Height AFFL	Vertical Rotation	Horizontal Rotation
⊗-I	A1	62W LED, DALI, Dimmable	2700K	Building Mounted	6m	30deg above horizontal	30 deg
⊗	A2	31W LED, DALI, Dimmable	2700K	Wall Mounted	2.5m	45deg above horizontal	30 deg
⊗-I	B1	25W LED, DALI, Dimmable	2700K	Building Mounted	3m	Nil	Nil
⊗-I	B2	25W LED, DALI, Dimmable	2700K	Building Mounted	5.5m	Nil	Nil
- -	D1	3.3W LED, DALI, Dimmable	2700K	Handrail	1m	Nil	Nil
- -	D2	3.3W LED, DALI, Dimmable	2700K	Wall Mounted	1m	Nil	Nil
⊕	F1	11W LED, DALI, Dimmable	2700K	Bollard	1.1m	Nil	Nil

**Key**  
Isolines Lighting Contours

- 1.0 lx
- 2.0 lx
- 3.0 lx
- 4.0 lx
- 5.0 lx
- 10.0 lx
- 20.0 lx

Note: Suffix "E" identifies luminaires that will be activated in emergency situations. These luminaires to be wired to the Central Battery system. For Example, "A1E" identifies a luminaire of type A1 (As Above) which will be activated in emergency situations.



**FOR INFORMATION**

Rev	Description	Drawn	Checked	Con App	HS2 App	Scale with caution as distortion can occur.
P01	EAR-CW_Schedule 17 Submission	AB	SK			© Crown Copyright and database right 2018. All rights reserved. Ordnance Survey Licence number 100049190
P02	EAR-CW_Schedule 17 LA Submission	MR	CE			© Crown Copyright material is reproduced with the permission of Land Registry under delegated authority from the Controller of HMSO. This material was last updated on 2018 and may not be copied, distributed, sold or published without the formal permission of Land Registry. Only an official copy of a title plan or register obtained from the Land Registry may be used for legal or other official purposes.
P03	EAR-CW_Schedule 17 Final Submission	TB	SK			
C01	EAR-CW_Schedule 17 Final Submission	TB	SK	GR		

**Legends/Notes:**  
 G1. All dimensions are in millimetres unless noted otherwise.  
 G2. All levels are in metres relative to OD (Ordnance Datum, Newlyn) unless noted otherwise.  
 G3. Chainages are expressed in metres and measured from Euston Station.  
 G4. Global coordinates are indicated by Eastings (E) and Northings (N) to the project snake grid.  
 G5. All angles are in degrees (0°-360°) unless noted otherwise.  
 G6. Dimensions are not to be scaled from the drawing.  
 G7. For the scope of works by the rail systems contractor, as indicatively shown on the drawings, refer to WI 100

- For Zones and Controls Layout refer to Drg No. 1MC03-SCJ\_SDH-EL-DGA-SS02\_SL01-440451.
- For layout drawing showing lux levels when the site is unoccupied, refer to Drg No. 1MC03-SCJ\_SDH-EL-DGA-SS02\_SL01-440453.
- For Lighting and Installation Details refer to Drg No. 1MC03-SCJ\_SDH-EL-DDE-SS02\_SL01-444451.
- Drawing to be read in conjunction with Landscape General Arrangement Drg No. 1MC03-SCJ\_SDH-LS-DGA-SS02\_SL01-441001.
- This drawing to be used for HS2 Schedule 17 planning applications only. This drawing is not for use for construction.

**HS2**  
 Registered in England Registration No. 06791686  
 Registered office: 2 Snow Hill, Queensway, Birmingham, B4 6GA  
**OFFICIAL**  
 Creator/Oriinator  
 SCS JV - Design House

Zone	Adelaide Road Vent Shaft			Project/Contract	HS2-MWCC SCS Sector S1		
Design Stage	Detailed Design			Discipline/Function	Electrical		
Drawing Title	Adelaide Road Vent Shaft Schedule 17 Plans and Specifications External Lighting Lux Levels Site Occupied For Information			Drawn	Checked	Approved	
	T Burrige	S King	C Gomez		Date	Scale	Size
	04/04/22	1:250	A1		Drawing No.	Rev.	
	1MC03-SCJ_SDH-EL-DGA-SS02_SL01-440452			C01			