

110mmØ SVP F/A T/B -

DOMESTIC WATER SERVICES PIPEWORK AT HIGH LEVEL	
DOMESTIC WATER SERVICES PIPEWORK DROPS FROM H/L TO L/L FROM LEFT TO RIGHT 22Ø BCWS 22Ø DHWS F 15Ø DHWS R ALL VALVES INSTALLED IN THE VERTICAL PIPEWORK ACCESS REQUIRED.	
SUPPLY AIR VALVE	
EXTRACT AIR VALVE	SUPPLY 125 Ø
VRF FAN COIL UNIT TO BE MOUNTED ABOVE THE BULKHEAD	SUPPLY 125Ø
NOX/CARBON FILTER 750mm(W) x 300mm(D) x 145mm(H)	
ACCESS PANEL 850mm(W) x 400mm(D)	

HIGH LEVEL

- 1. THIS DRAWING MUST NOT BE USED FOR CONSTRUCTION OR INSTALLATION PURPOSES UNLESS EXPRESSLY STATED.
- 2. ALL INFORMATION AND LAYOUT ON THIS DRAWING IS SUBJECT TO SITE DIMENSION CHECKS. DO NOT SCALE FROM THIS DRAWING ALWAYS WORK TO NOTED DIMENSIONS.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS NOTED OTHERWISE.
- 4. ALL DIMENSIONS MUST BE VERIFIED ON SITE BEFORE COMPLETING SHOP DRAWINGS OR SETTING OUT THE WORKS.
- 5. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTS, STRUCTURAL ENGINEERS, MEP CONSULTANT DRAWINGS AND SPECIFICATIONS.
- 6. ANY DISCREPANCIES BETWEEN DRAWINGS AND SPECIFICATION OR RELATED DOCUMENT, THE ENGINEER SHALL BE NOTIFIED IN WRITING FOR VERIFICATION OF DISCREPANCY.
- 7. SERVICE PENETRATIONS WITHIN FIRE RATED PARTITIONS SHALL BE FIRE STOPPED IN ACCORDANCE WITH THE SPECIFICATION.

C3	CONTRACT ISSUE	23.12.20
C2	DRAWING REVISED TO SUIT THE ARCHITECTS LAYOUT	20.11.20
C1	CONTRACT ISSUE	31.07.20
Т2	STAGE 4 - TENDER ISSUE	22.11.19
T1	STAGE 4 - TENDER ISSUE	25.10.19
Revision	Description	Date

wing Status:

CONTRACT

PSH.

London Office 4th Floor, Alto Tower, 30 Stamford Street, London. SE1 9LQ T. 0203 039 3840

Wokingham Office 6 Alexandra Court, Wokingham Berkshire. RG40 2SL

T. 0118 977 4747 E. info@pshconsulting.co.uk E. info@pshconsulting.co.uk

www.pshconsulting.co.u

MORRIS + COMPANY

lient:

rchitect:

DEMAR HOLDINGS

oject:

115 - 119 CAMDEN HIGH STREET

TYPICAL HOTEL ROOM TYPE 1.1 HIGH AND LOW LEVEL MECHANICAL SERVICES LAYOUT

Drawn:	Chkd/Appd:	Date:
JTC	AP	01.08.19
Cad File: 3187-PSH-H-TY-DR-M-8002.DWG		Scale: 1:20@A1
Drawing Number:		Rev:
3187-PSH-H-TY-DR-M-8002		C3

600x600mm ACCESS PANEL REQUIRED

MECHANICAL VENTILATION HEAT RECOVERY UNIT 534mm(W) x 552mm(D) x 221mm(H)

INSULATED FRESH AIR INTAKE & DISCHARGE DUCTS CONNECT TO A COMBINED INTAKE & DISCHARGE LOUVRE VIA SEPARATE INTERNALLY LINED PLENUM BOXES. LOUVRE AND PLENUM BOX TO BE SPECIFIED BY THE ARCHITECT