

Conservation Area Advisory Committee

Advisory Committee	Camden Town
Application ref	2022/1855/L
Address	30 Albert Street London Camden NW1 7NU
Planning Officer	Ewan Campbell
Comments by	29 May 2022
Proposal	Replacement of existing timber framed windows with new timber framed windows. Roof repairs and removal of two satellite dishes. Full Planning Permission under 2021/0808/P
Objection	Yes
Observations	<p>The CTCAAC is concerned to note that no DAS or Heritage Impact Assessment has been submitted in support of this application. There are also no 1:5 details of the new timber sash windows and therefore we are unsure if sightlines will be preserved. This should be conditioned if a drawing is not submitted as part of this application.</p> <p>The plans state that both 2nd & 3rd floor windows are to be replaced with others repaired, however on the elevations only the top floor windows are to be replaced, the rest repaired. We would urge maximum retention of existing joinery - repairing is more sustainable than replacement.</p> <p>Committee members are also very disappointed that the proposals do not include any provision for upgrading thermal fabric to improve U values for tenants / leaseholders. No consideration appears to have been made to address climate change and as Camden has itself declared a climate emergency, this should be a requirement for all such applications going forward.</p>

Documents attached

No details entered

About this form

Issued by	Contact Camden 5 Pancras Square London N1C 4AG
Form reference	21760221

Data Protection

No personal information you have given us will be passed on to third parties for commercial purposes. The Council's policy is that all information will be shared among officers and other agencies where the legal framework allows it, if this will help to improve the service you receive and to develop other services. If you do not wish certain information about you to be exchanged within the Council, you can request that this does not happen.