

Application No:	Consultees Name:	Received:	Comment:	Response:
2022/0655/P	Iain Clark	13/05/2022 15:22:53	COMMNT	The existing cladding materials and inadequate barriers on this building currently give rise to an increased risk of rapid fire spread across the facade to affect multiple dwellings. The Private Sector Housing Team fully supports the proposals to replace the existing cladding and insulation materials with materials which have a classification of A2 -S1, d0 or better and to fit appropriate cavity and fire barriers so that the facade fully complies with the requirements of current Building Regulations
