


Details			
Project:	Kings Cross W Zone Development	Global MARF Number:	MARF-1002 – Aluminium Wicona WICLINE75 Evo Side Hung Window Frame_rev02
		Contract number:	21A00060
Sender:	Midgard Ltd	Date sent:	10/11/2021
Contact for further information if required:	Name:		Wojciech Wolsza
	Phone:		+44 7827 929 204
	Email:		wojciech.wolsza@mcmullenfacades.com
Subcontractor:		McMullen Facades Ltd	
Specified product:		Window Frames Side Hung Window with transom	
Proposed product:		WICLINE75 Evo Aluminium Windows	
Product Specification/Technical Data:	Wicona RAL 1035 30% gloss Finish		
Manufacturer:		McMullen Facades Ltd	
Supplier:		McMullen Facades Ltd	
Batch number/other Identification:		N/A	
Planned date for inclusion to the works:		For Planning Date 12.04.2021	
Part of works element:		General	
Contract specification:		ER's reference	
Drawing Reference:		N/A	
Deviation from current Specification:		New proposal or as per contract	
Attachments			
Test Certs:	N/A		
Technical Literature:	Refer to MCM Technical Submittal ref. KXC-MFL-TS-001		
Samples:	Sample available on Site.		
Photos:			

Midgard Comments

2021-09-08 MID: RAL 1035 30% gloss Finish for W2 Ground Floor
2021-10-06 DMA: Sample to be agreed once comments are addressed on technical submittal which is currently status C. Confirm if sample is representative of new proposal with internal stiffener?
2021-11-05 MID: Please see MCM response datasheet attached to revised MARF 1002_rev02 for CMT comments/approval.

Client Comments

\

Client Monitoring Team (CMT) Observation Status

Approval Status:
 A Submission reviewed with no comments
 B Submission reviewed and accepted subject to incorporation of comments
 C Submission reviewed and rejected
 N Submission reviewed and no longer relevant or required
 Comments: (enter 'no comment' if applicable)
[Click here to enter text.](#)

Signatures for Proceed

Client Name:		Company:	
Signature:		Date:	
Client Rep Name:		Company:	
Signature:		Date:	
Lead Reviewer:		Company:	
Signature:		Date:	
Main Contractor:		Company:	
Signature:		Date:	

ASFD-McMullen Façade Ltd Responses to CMT comments:

Item	Chapter – Page	CMT Comments 06/10/2021	ASFD – Response 01/11/2021
01	Page 01	FMDC: a technical submittal for the coatings shall be made available.	-TS for coatings is now available please refer to KXC-MFL-TS-005.
02	Page 01	this reference is not correct	- Correct reference is TS-001
03	Page 02	RAL 1035 is for W2 upper levels. Are samples going to be produced for W1?	-There is no plans of submitting this MARF in more colour options. This MARF is intended for the approval of the Window system, and the sample is Powder coated for representation of the surfaces coated. -For comments related to PPC and Colours please refer to the PPC specific MARFs. where all project colours are captured.
04	Page 02	Sample to be agreed once comments are addressed on technical submittal which is currently status C. Confirm if sample is representative of new proposal with internal stiffener?	-TS-001 is now Status "B", with minor comments -This window is still representative of windows in the project. -Separate submittal will cover the Stiffener profile