







For Planning
 These drawings are not for construction.
 Check all dimensions on site. Do not scale off drawings without prior consultation. Any discrepancies to be reported to architects before execution of relevant works. This drawing has been produced for the development at The Coach House and for this project alone and is not intended for use by any other person or for any other purpose. Drawings remain copyright of Ludwig Willis Architects and may not be reproduced without written consent or licence.

Notes:

-  Existing building fabric
-  Proposed building fabric

Key:

-  Mains operated smoke detectors
-  Mains operated heat detectors
-  Egress Route
-  30 minute fire Door



Issue / Revision

P01 11/04/2022 For Information

LudwigWillis Architects

Project
 The Coach House
 Fawley Road
 NW6 1SN

Fire Safety Plan
 Part B Diagram

31/05/2022
 1:100
 A3

041_DIG_101_P01
 For Planning

Egress Window 01
 Opening sash window
 Openable area:
 1094x655mm = 0.72m²
 Sill height from internal
 FFL: 812mm
 Vertical escape distance
 FFL to external ground:
 3021mm

Egress Window 02
 Opening sash window
 Openable area:
 1188x655mm = 0.78m²
 Sill height from internal
 FFL: 812mm
 Vertical escape distance
 FFL to external ground:
 3207mm

