


Plan




Low sound enclosure by Daikin


- Specification:
- Double layer of powder coated finishing :
 - First layer - epoxy primer
 - Second layer - polyester
 - 70-160mm thick high quality sound insulating material.
 - Multi directional flexible piping connections.
 - Optional drain pan and heater.



Front elevation of unit



Side elevation of unit



Dimensions Written dimensions to be taken in preference to scaled dimensions. The Contractor is responsible for checking all dimensions before work starts.

Local Authority All work is to be carried out to the requirements, and to the satisfaction of the Local Authority. These drawings are for planning purposes only.

Discrepancies Any discrepancies to be brought to the attention of Drawing And Planning Ltd. Immediately.

REVISIONS					
REV	DATE	DESCRIPTION	BY	CH	

PROJECT TITLE 5 Pilgrim's Lane	
DATE May 2022	REVISION /

DRAWING TITLE Proposed- Sound enclosure detail	
CLIENT Alison Jane Baker	
DRAWING No. PILNE-D401	SCALE @ A3 1:20

