



Doran Consulting
Norwood House
96 - 102 Great Victoria Street
Belfast
BT2 7 BE



19 January 2021

Pre-planning enquiry: Confirmation of sufficient capacity

Dear Mr McGrath,

Thank you for providing information on your development.

Site: Highgate Newtown Community Centre, 25 Bertram Street, London, N19 5DQ.

Proposed site: Redevelopment of site for 41 flats and 284m² sports hall.

Proposed foul water: To discharge via gravity to 375mm public combined water sewer to north of site.

Proposed surface water: Surface water discharge via gravity limited to a total of 10l/s. 5l/s to 375mm public combined water sewer to north of site and 5l/s to 1168mm x 762mm public combined water sewer in Winscombe street.

We have completed the assessment of the foul water flows and surface water run-off based on the information submitted in your application with the purpose of assessing sewerage capacity within the existing Thames Water sewer network.

Foul Water

If your proposals progress in line with the details you've provided, we're pleased to confirm that there will be sufficient sewerage capacity in the adjacent combined water sewer network to serve your development.

This confirmation is valid for 12 months or for the life of any planning approval that this information is used to support, to a maximum of three years.

You'll need to keep us informed of any changes to your design – for example, an increase in the number or density of homes. Such changes could mean there is no longer sufficient capacity.

Surface Water

When developing a site, policy 5.13 of the London Plan and Policy 3.4 of the Supplementary Planning Guidance (Sustainable Design And Construction) states that every attempt should be made to use flow attenuation and SuDS/Storage to reduce the surface water discharge from the site as much as possible.

In accordance with the Building Act 2000 Clause H3.3, positive connection of surface water to a public sewer will only be consented when it can be demonstrated that the hierarchy of disposal

methods have been examined and proven to be impracticable. Before we can consider your surface water needs, you'll need written approval from the lead local flood authority that you have followed the sequential approach to the disposal of surface water and considered all practical means.

The disposal hierarchy being:

1. store rainwater for later use.
2. use infiltration techniques where possible.
3. attenuate rainwater in ponds or open water features for gradual release.
4. attenuate rainwater by storing in tanks or sealed water features for gradual release.
5. discharge rainwater direct to a watercourse.
6. discharge rainwater to a surface water sewer/drain.
7. discharge rainwater to the combined sewer.
8. discharge rainwater to the foul sewer

Where connection to the public sewerage network is still required to manage surface water flows we will accept these flows at a discharge rate in line with CIRIA's best practice guide on SuDS or that stated within the sites planning approval.

If the above surface water hierarchy has been followed and if the flows are restricted to a total rate of 10l/s as described above then Thames Water would not have any objections to the proposal.

What happens next?

Please make sure you submit your connection application, giving us at least 21 days' notice of the date you wish to make your new connection/s.

If you've any further questions, please contact me on 020 3577 9223.

Yours sincerely



Alan Dovey
Development Engineer
Developer Services – Sewer Adoptions Team

Get advice on making your sewer connection correctly at connectright.org.uk

Clearwater Court, Vastern Road, Reading, RG1 8DB

Find us online at developers.thameswater.co.uk