

Application No:	Consultees Name:	Received:	Comment:	Response:
2022/2874/P	Richard Simpson for Primrose Hill CAAC	03/08/2022 20:40:45	OBJ	<p>PRIMROSE HILL CONSERVATION AREA ADVISORY COMMITTEE 12A Manley Street London NW1 8LT</p> <p>3 August 2022</p> <p>29 Fitzroy Road NW1 8TP      2022/2874/P</p> <p>Objection.</p> <ol style="list-style-type: none"> <li>1. The stone used for the two sets of steps needs to be specified: York stone would be appropriate, riven not sawn preferably.</li> <li>2. the screen to the lower ground floor, under the steps, needs to be more traditional in the sections used in the framing to work with the window frames.</li> <li>3. the tiles to the area need to be specified and approved.</li> <li>4. The sections of the proposed replacement window frames to the front elevation need to be provided at large scale and approved.</li> </ol> <p>Richard Simpson FSA Chair</p>
2022/2874/P	Richard Simpson for Primrose Hill CAAC	03/08/2022 20:40:40	OBJ	<p>PRIMROSE HILL CONSERVATION AREA ADVISORY COMMITTEE 12A Manley Street London NW1 8LT</p> <p>3 August 2022</p> <p>29 Fitzroy Road NW1 8TP      2022/2874/P</p> <p>Objection.</p> <ol style="list-style-type: none"> <li>1. The stone used for the two sets of steps needs to be specified: York stone would be appropriate, riven not sawn preferably.</li> <li>2. the screen to the lower ground floor, under the steps, needs to be more traditional in the sections used in the framing to work with the window frames.</li> <li>3. the tiles to the area need to be specified and approved.</li> <li>4. The sections of the proposed replacement window frames to the front elevation need to be provided at large scale and approved.</li> </ol> <p>Richard Simpson FSA Chair</p>