



LEAD FLASHING TO BE REPAIRED/  
REPLACED WHERE DAMAGED

BRICK POINTING REPAIRS  
TO BE CARRIED OUT  
TO EAST ELEVATION

SKYLIGHTS FLASHING  
TO BE REPLACED

DAMAGE ON FACE  
OF CHIMNEYPOT  
TO BE REPAIRED

SLATE ROOF TO BE REPLACED

SLATE ROOF AGED AND WEATHERED  
REQUIRED REPLACEMENT TO INCLUDE:  
- LIKE-FOR-LIKE SLATE ROOFING TILES  
- SUBSTRATE ROOFING REPLACEMENT  
- NEW LEAD FLASHING TO REPLACE EXISTING  
AROUND CHIMNEYS AND JOINTS  
- NEW LEAD FLASHING TO RE-SEAL EXISTING  
SKYLIGHTS



ROOF PLAN DETAIL



SCALE BAR (METRES)

NO:	REVISION:	DATE:
CLIENT/PROJECT:		
75 FLASK WALK LONDON, NW3 1ET		
SHEET TITLE:		
ROOF PLAN DETAIL		
SCALE:	1:50 (A3)	Do not scale. Contractor to verify all dimensions on site and report errors and omissions to designers before commencing work.
DATE:	08/08/2022	
DRAWING SERIES NO:		
75FW - ROOF 1002		

**MEIKLE**  
| design | management | architectural |  
| Keith Meikle | info@keithmeikle.com |