N

Chalk Farm Road

MAIN PERFORMANCE SPACE 1001

VOID

BRIDGE No.1

BRIDGE No.2

BAR 1060

GALLERIA FOYER 1067

GALLERIA 1066

PLANT ROOM 1058

PLANT 1056

LIFT LG2

LIFT LG1

LIFT LP1

STAIR No.1 1061

STAIR No.2 LOBBY 1069

STAIR No.3 1062

STAIR No.4

STAIR No.7

DAY CELLAR 1063

FRONT OF HOUSE AND FIRST AID 1060

SECURITY OFFICE 1068

LOADING DOCK 1075

LOBBY 1074

DIS. WC / BABY CHANGE 1021

WC FEMALE 1003

WC MALE 1002

CORRIDOR 1040

CORRIDOR 1045

CORRIDOR 1044

CORRIDOR 1043

CORRIDOR 1054

CORRIDOR 1071

CORRIDOR 1072

DRESSING ROOM 1047

DRESSING ROOM 1050

DRESSING ROOM 1051

DRESSING ROOM 1052

DRESSING ROOM 1053

LAUNDRY 1014

DISABLED WC 1073

TECH STAFF 1121

CLEANER'S STORE 1035

CLEANER'S STORE 1035A

DISABLED WC / BABY CHANGING 1033

PRODUCTION OFFICE 1031

TEMPORARY PLANT 1030

DIMMER AMP ROOM 1023

PLANT 1022

DETECTOR MOUNTED WITHIN 1500 OF LIFT SHAFT

FINAL LOCATION TO BE CONFIRMED ON SITE AFTER PLANT INSTALLATION

STAFF ALERT SIGNAL POINT. THE FINAL LOCATION TO BE AGREED WITH USER

STAFF ALERT SIGNAL POINT. THE FINAL LOCATION TO BE AGREED WITH USER

ACCESS CONTROL INTERFACE UNIT. TO MAGNETIC DOOR LOCK

2No. MAGNETIC DOOR HOLD OFF OVERIDE SWITCHES, FOR LEVEL 1 AND LEVEL 2 PERFORMANCE SPACE DOORS

DETECTOR MOUNTED WITHIN 1500 OF LIFT SHAFT.

STAFF ALERT SIGNAL POINT. THE FINAL LOCATION TO BE AGREED WITH USER

FOR DETAILS OF PROTECTION TO THE MAIN PERFORMANCE SPACE REFER TO DRG No 50098/E/3030

ASPIRATION CONTROL UNIT

ASPIRATION UNIT CONTROL

STAFF ALERT SIGNAL POINT. THE FINAL LOCATION TO BE AGREED WITH USER

STAFF ALERT SIGNAL POINT. THE FINAL LOCATION TO BE AGREED WITH USER

FOR DETAILS REFER TO DRG No 50098/E/6140

LINE OF 20 FT OFFSET FROM BOUNDARY

LOW CLOSED BORDED TIMBER FENCE

OVERHEAD HIGH TENSION CABLE

NOTES

LEGEND

- FIRE ALARM REPEATER PANEL
- CALL POINT
- MICROPHONE
- FLASHING BEACON (NOT XENON)
- H — HEAT DETECTOR
- S — SMOKE DETECTOR
- S V — VOID DETECTOR MOUNTED IN ZONES BETWEEN BEAMS AND ABOVE FALSE CEILING
- LOUDSPEAKER
- CALL POINT WITH VISUAL INDICATION OF ACTIVATION AND LABEL
- STAFF ALERT SIGNAL POINT C/W TWIN PULSATING LAMP AND AUDIBLE ALARM DEVICE
- ASPIRATION AIR PIPEWORK SAMPLING SYSTEM
- ASP — VESDA LASER COMPACT CONTROL UNIT
- IU/HO — INTERFACE UNIT AND MAGNETIC HOLD OFF DEVICE FOR SMOKE CURTAINS
- IU — INTERFACE UNIT
- MD — MAGNETIC DOOR HOLD OFF
- K — KEY SWITCH MANUAL OVERIDE FOR MAGNETIC DOOR HOLD OFF
- HS — SWITCHABLE HEAT/SMOKE DETECTOR
- CAPILLARY TUBE
- WCR — WHEELCHAIR REFUGE INTERCOM
- WCH — WHEELCHAIR REFUGE SLAVE HANDSET
- BI-DIRECTIONAL SPEAKER
- I / D — DEVICES MARKED THUS INDICATE ISOLATED OR DELAYED IN PERFORMANCE MODE
- area for licensable activities

REV	DATE	DESCRIPTION
C	04.08	Isolated or Delayed Devices Indicated
B	08.07	Dressing Room Smoke Detectors Changed To Heats

gbe Fire & Security
Dark Mills
Brimscombe
Stroud
Glos GL5 2TE
Phone: 0845 1220844
Fax: 0845 1220845
E-mail: info@gbe-uk.com
Website: www.gbe-uk.com

STATUS: AS FITTED

CLIENT: INTERSERVE ENG.

PROJECT: THE ROUNDHOUSE THEATRE

TITLE: Licensing
LEVEL 1
FIRE ALARM LAYOUT
10.08.22

SCALE: NTS	DESIGNED: SK
PROJECT NUMBER: 0057-2003	DRAWN: GW
DATE: 01.04.08	CHECKED: SK
DRAWING NUMBER: E3020GBE	REVISION: C