

Conservation Area Advisory Committee

Advisory Committee	Belsize
Application ref	2022/2738/P
Address	62 Hillfield Court Belsize Avenue London NW3 4BG
Planning Officer	Obote Hope
Comments by	04 Sep 2022
Proposal	Replacement of windows from single glazing metal framed windows to double glazing uPVC windows which match the neighbouring flats's windows.
Objection	Yes
Observations	Objection Replacement windows should be in metal to match the original. Glazing bars should be no thicker than for single glazing. David Thomas for BCAAC

Documents attached

No details entered

About this form

Issued by	Contact Camden 5 Pancras Square London N1C 4AG
Form reference	21774319

Data Protection

No personal information you have given us will be passed on to third parties for commercial purposes. The Council's policy is that all information will be shared among officers and other agencies where the

Data Protection

legal framework allows it, if this will help to improve the service you receive and to develop other services. If you do not wish certain information about you to be exchanged within the Council, you can request that this does not happen.