

PROPOSED LICENSING LAYOUT

SCALE 1:50

500 1000 1500 2000 3000 4000mm

LICENSING KEY	
	INDICATES INTERNAL AREA OF LICENSABLE ACTIVITIES
	INDICATES EXTERNAL AREA OF LICENSABLE ACTIVITIES
W	WATER FIRE EXTINGUISHER
СО ² 2.0Кg	CO2 FIRE EXTINGUISHER
F	FOAM FIRE EXTINGUISHER
W.C 6L	WET CHEMICAL FIRE EXTINGUISHER
FB	FIRE BLANKET
CP	MANUAL FIRE ALARM CALL POINT
FIRE EXIT	LOCATION OF FIRE EXIT DOOR
•	SMOKE DETECTOR
Э	HEAT DETECTOR
	FIRE ALARM SOUNDER
	DISABLED ALARM
PANIC	FINAL EXIT FLOOR FITTED WITH PANIC BAR & LATCH NOTE: ALL DOORS ON ESCAPE ROUTES TO HAVE SINGLE ACTION MECHANISM WITH NO RECOURSE TO A KEY. IF ALARMED CONTRACTOR TO INSTALL SUFFICIENT SOUNDERS TO ENSURE THAT ALARM IS AUDIBLE THROUGHOUT PREMISES
E	EMERGENCY LIGHTING
S14	KEEP DOOR LOCKED SIGN NOTE: ON DIRECTION OF OPENING SIDE
NOTE:	

The location and type of any Fire Safety equipment will be advised by the Fire Safety Consultant. This may be subject to change following the completion of the works or following the Fire Officer/Appointed Fire Safety Consultant's assessment. Layouts may also be varied from time to time with the agreement of the Fire Officer or after any further Fire Risk Assessment. Management and Fire Safety Strategy advice must be incorporated into the new scheme.

SWISS COTTAGE ~ 1. THIS DRAWING MUST <u>NOT</u> BE SCALED. 2. FOLLOWING COMMENCEMENT OF WORK ON SITE, ISSUED DRAWINGS AND DETAILS MAY BE SUBJECT TO CHANGE DUE TO SITE CONDITIONS OR S CONTRACTOR DESIGN MODIFICATIONS. 3. ALL WORKS <u>MUST</u> <u>BE</u> CARRIED OUT TO THE SATISFACTION OF LOCAL AND STATUTORY AUTHORITIES, IN ACCORDANCE WITH CURRENT BUILDING REGULATIONS AND CODES OF PRACTICE. Ш Z 4. ALL DIMENSIONS ARE TO BE VERIFIED WITH THE CONTRACTOR ON SITE PRIOR TO MANUFACTURE G OR INSTALLATION. 5. QUADRANT DESIGN MUST BE INFORMED OF ANY AMENDMENTS TO THE DESIGN ON SITE. SCAN THIS CODE TO ACCESS: QD WEBSITE

SCAN ME

