



**P1 - Partition to bar pocket door**  
 1 x 12.5mm Fermacell board  
 75mm DIN SteelStuds  
 ECLISSE SINGLE POCKET DOORS SYSTEM for a 44mm sliding pocket door or equivalent approved from eg:  
<https://ironmongerydirect-assets.s3.amazonaws.com/product-documentation/technical/867061.pdf>  
 1 x 12.5mm Fermacell board  
 Partition thickness: 100mm  
 Partition height: max. 2140mm

Partition to bar pocket door

**P2 - Curved wall to Stalls Boxes**  
 1 x 12.5mm Fermacell board  
 50mm DIN SteelStuds @400mm centres  
 1 x 12.5mm Fermacell board  
 Radius: 16500mm  
 Allow for 25mm deflection head detail to be confirmed by Structural Engineer  
 Partition thickness: 75mm  
 Partition height: max. 3420mm

Partitions to front of Stalls Boxes

**P3 - Wall type FR60, 60dB**  
 2 x 12.5mm Fermacell boards  
 50mm DIN SteelStuds @600mm centres  
 50mm Rockwool RWA45 45kg/m3  
 2 x 12.5mm Fermacell boards  
 Allow for 25mm deflection head detail to be confirmed by Structural Engineer  
 Partition thickness: 100mm  
 Partition height: max. 2700mm

Partitions to GF lift, Box Office and new DB cupboard

**P4 - Wall type FR60, 62dB**  
 2 x 12.5mm Fermacell boards  
 75mm DIN SteelStuds @600mm centres  
 2 x 12.5mm Fermacell boards  
 50mm Rockwool RWA45 45kg/m3  
 2 x 12.5mm Fermacell boards  
 Allow for 25mm deflection head detail to be confirmed by Structural Engineer  
 Partition thickness: 125mm  
 Partition height: max. 3350mm

Partitions to LGF bar area and Sub-Stage new Dimmer Room

**L1 - Wall lining**  
 1 x 12.5mm Fermacell board  
 50mm DIN SteelStuds @400mm centres  
 Allow for 18mm ply pattressing where sanitaryware items or tiling are installed as required  
 Allow for uncoupling membrane to be installed where tiles are applied e.g. Schluter KERDI / KERDI-KEBA  
<https://www.schluter.co.uk/kerdi-kerdi-keba.aspx>  
 or equivalent approved  
 Partition thickness: 62.5mm  
 Partition height: max. 3000mm

Allow for access tiled hatches to new services to M+E details as required  
 Accessible WC and new jet diffusers bulkhead in front Stalls boxes

**L2 - FR60 Wall lining**  
 2 x 12.5mm Fermacell boards  
 50mm DIN SteelStuds @400mm centres  
 Allow for 18mm ply pattressing where required where wall mounted equipment is installed.  
 50mm Rockwool RWA45 45kg/m3  
 Partition thickness: 75mm  
 Partition height: max. 3000mm

Accessible WC and new jet diffusers bulkhead in front Stalls boxes

**PARTITION TYPES**

P1	Bar pocket door
P2	Curved wall to Boxes
P3	FR60, 60dB Partition
P4	FR60, 60dB Partition
P5	Tiled wall lining
P6	FR60 Wall lining

**Note:**  
 Allow for fire rated penetration details, head deflection and base details to all fire rated walls and linings to retain the fire rating across ALL Fire Rated partition elements.  
 Allow for pattressing as required where elements are to be wall mounted e.g. DB, bar area where shelves, FCUs are installed etc.  
 Reinstate existing skirtings where affected by the works.  
 Allow for new skirtings to new partitions to match existing skirtings in Stalls.

See drawings 1601-5-109 to 112 for partition location  
 See drawings 1601-5-510 for partition and lining details.

THE CONTRACTOR IS TO CHECK AND VERIFY ALL BUILDING AND SITE DIMENSIONS, LEVELS AND SEWER INVERT LEVELS AT CONNECTION POINTS BEFORE WORK STARTS

THIS DRAWING IS TO BE READ AND CHECKED IN CONJUNCTION WITH ENGINEERS AND OTHER SPECIALIST DRAWINGS

THE DRAWING AND THE WORKS DEPICTED ARE THE COPYRIGHT OF THIS PRACTICE AND MAY NOT BE REPRODUCED EXCEPT BY WRITTEN PERMISSION



Rev:	Date:	Description
/	20/09/22	Planning

**Job:** 2201 Ambassadors Theatre  
**Client:** Ambassador Theatre Group

**Drawing:** Proposed Wall Build-up Types  
**Drawing no:** 2201-3-510  
**Scale:** 1:5 @ A1 1:10 @ A3  
**Rev:** Stage 3  
**Status:** Date: 20/09/22

**citizensdesignbureau**  
 Ground Floor Units 01 & 03, 6 Westgate Street, London, E8 3RN  
 t : 02030959732  
 e : everyone@citizensdesignbureau.net