



33 Theobalds Road, WC1X 8SP

10th August 2022

ISSUE 01





CONTENTS

1	INTRODUCTION	3
2	NOISE CRITERIA	4
	2.1 NATIONAL PLANNING POLICY FRAMEWORK (2018)	4
	2.2 NOISE POLICY STATEMENT FOR ENGLAND	4
	2.3 PLANNING POLICY GUIDANCE	5
	2.4 BRITISH STANDARD 4142:2014	5
	2.5 LOCAL AUTHORITY REQUIREMENTS	7
3	SITE SURVEYS.....	8
	3.1 SITE DESCRIPTION	8
	3.2 ENVIRONMENTAL SITE SURVEY PROCEDURE	8
4	EQUIPMENT	9
5	NOISE SURVEY	10
6	NOISE IMPACT ASSESSMENT.....	11
	6.1 INSTALLED PLANT.....	11
	6.2 CLOSEST NOISE SENSITIVE RECEIVER.....	13
	6.3 MITIGATION MEASURES.....	14
	6.4 BA4142 ASSESSMENT	15
7	SUMMARY AND CONCLUSIONS.....	16
APPENDIX:		
A	ACOUSTIC TERMINOLOGY.....	17
B	MEASUREMENTS	19
C	CALCULATIONS	20
D	NOISE DATA	22

Author	Date	Checked	Date	Description
L. Jennings Tec. IOA	10/08/2022	M.Austin l.Eng. MIOA	31/08/2022	Information.
<p>This report has been compiled by Deane Austin Ltd (DAA) with all reasonable skill, care and diligence in accordance with generally accepted acoustic consultancy principles. Information contained in this document contains confidential and commercially sensitive information and shall not be disclosed to third parties.</p>				



1.0 INTRODUCTION

DAA Group has been appointed to carry out a Noise Impact Assessment at 33 Theobalds Road, WC1X 8SP to support a Planning Application for the Installation of a new kitchen extract system and retention of installed plant.

The purpose of the survey is to ensure that the development does not prejudice the amenities of occupiers of nearby premises in accordance with the provisions of:

- The National Planning Policy Framework, the Noise Policy Statement for England (NPSE)
- The World Health Organisation Guidelines for Community Noise 1999 (WHO)
- London Plan 2021
- The Environmental Health legislation 'the Control of Odour and Noise from Commercial Kitchen Exhaust Systems (2018).'
- The London Borough of Camden Local Plan 2017

The technical content of this assessment has been provided by a Tech member of the Institute of Acoustics.

The Institute of Acoustics is the UK's professional body for those working in Acoustics, Noise and Vibration.



2.0 NOISE CRITERIA

2.1 NATIONAL PLANNING POLICY FRAMEWORK (NPPF)

The Department for Communities and Local Government introduced the National Planning Policy Framework (NPPF) in March 2012. The latest revision of the NPPF is dated July 2018.

Page | 4

The NPPF sets out the Government's planning policies for England and how these are expected to be applied. It provides a framework where local Councils can produce their own local and neighbourhood plans which reflect the needs of their communities.

In conserving and enhancing the natural environment, the planning system should prevent both new and existing development from contributing to, or being put at, unacceptable risk from environmental factors including noise.

Planning policies and decisions should aim to avoid noise giving rise to significant adverse impacts on health and quality of life as a result of new development. Conditions may be used to mitigate and reduce noise to a minimum so that adverse impacts on health and quality of life are minimised. It must be recognised that development will often create some noise and existing businesses wanting to develop in continuance of their business should not have unreasonable restrictions put on them. Reference is made within NPPF to the Noise Policy Statement for England (NPSE) as published by DEFRA in March 2010.

2.2 NOISE POLICY STATEMENT FOR ENGLAND (NPSE)

The long-term vision of the NPSE is stated within the documents scope, to 'promote good health and a good quality of life through the effective management of noise within the context of Government policy on sustainable development'. The policy aims are stated to:

- avoid significant adverse impacts on health and quality of life;
- mitigate and minimise adverse impacts on health and quality of life; and
- where possible, contribute to the improvement of health and quality of life.

The application of NPSE should mean that noise is properly taken into account at the appropriate time (for example in planning applications or appeals) where it must be considered alongside other relevant issues. The guiding principles of Government policy on sustainable development should be used to assist in the implementation of the NPSE.

The NPSE should apply to all types of noise apart from occupational noise in the workplace. The types of noises defined in the NPSE includes:

- Environmental noise from transportation sources;
- Neighbourhood noise which includes noise arising from within the community; industrial premises, trade and business premises, construction sites and noise in the street

The Noise Policy Statement England (NPSE) outlines observed effect levels relating to the above, as follows:

- **NOEL – No Observed Effect Level**

o This is the level below which no effect can be detected. In simple terms, below

this level, there is no detectable effect on health and quality of life due to the noise.

- **LOAEL – Lowest Observed Adverse Effect Level**

- o This is the level above which adverse effects on health and quality of life can be detected.

- **SOAEL – Significant Observed Adverse Effect Level**

- o This is the level above which significant adverse effects on health and quality of life occur.

As stated in The Noise Policy Statement England (NPSE), it is not currently possible to have a single objective based measure that defines SOAEL that is applicable to all sources of noise in all situations. Specific noise levels are not stated within the guidance for this reason, and allow flexibility in the policy until further guidance is available.

2.3 ProPG: PLANNING AND NOISE

As outlined above, the National Planning Policy Framework encourages improved standards of design, although it provides no specific noise levels which should be achieved on site for varying standards of acoustic acceptability, or a prescriptive method for the assessment of noise.

ProPG: Planning and Noise was published in May 2017 in order to encourage better acoustic design for new residential schemes in order to protect future residents from the harmful effects of noise. This guidance can be seen as the missing link between the current NPPF and its predecessor, PPG24 (Planning Policy Guidance 24: Planning and Noise), which provided a prescriptive method for assessing sites for residential development, but without the nuance of 'good acoustic design' as outlined in ProPG.

ProPG allows the assessor to take a holistic approach to consider the site's suitability, taking into consideration numerous design factors which previously may not have been considered alongside the noise level measured on site, for example the orientation of the building in relation to the main source of noise incident upon it.

It should be noted this document is not an official government code of practice, and neither replaces nor provides an authoritative interpretation of the law or government policy, and therefore should be seen as a good practice document only.

2.4 BRITISH STANDARD 4142:2014+A1:2019

British Standard (BS) 4142:2014 "Methods for rating and assessing industrial and commercial sound" describes methods for assessing the likely effects of sound on premises used for residential purposes.

It includes the assessment of sound from industrial and manufacturing processes, M&E plant and equipment, loading and unloading of goods and materials, and mobile plant/vehicles on the site. It can be used to assess sound from proposed, new, modified or additional industrial/commercial sources, at existing or new premises used for residential purposes.

The method described in BS4142: 2014 use outdoor sound levels to assess the likely effects of sound on people who might be inside or outside a dwelling or premises used for residential purposes upon which sound is incident.

The standard describes methods to measure and determine ambient, background and residual sound levels, and the rating levels of industrial/commercial sound. BS 4142: 2014 requires consideration of the level of uncertainty in the data and associated calculations. BS 4142 is not intended to be used for the derivation or assessment of internal sound levels, or for the assessment of non-industrial / commercial sources such as recreational

activities, motorsport, music and entertainment, shooting grounds, construction and demolition, domestic animals, people, and public address systems for speech. The Reference Time Interval, T, is defined in the standard as the “specified interval over which the specific sound level is determined”, which is 1 hour during the daytime (07:00 to 23:00 hours) and 15 minutes during the night (23:00 to 07:00 hours).

Ambient sound is defined in BS 4142: 2014 as "totally encompassing sound in a given situation at a given time, usually composed of sound from many sources near and far". It comprises the residual sound and the specific sound when present.

Residual sound is defined in BS 4142: 2014 as "ambient sound remaining at the assessment location when the specific sound source is suppressed to such a degree that it does not contribute to the ambient sound".

The background sound level is the LA90, T of the residual sound level, and is the underlying level of sound. Measurements of background sound level should be undertaken at the assessment location where possible or at a comparable location.

The measurement time interval should be sufficient to obtain a representative value (normally not less than 15 minutes) and the monitoring duration should reflect the range of background sound levels across the assessment period. The background sound level used for the assessment should be representative of the period being assessed.

The specific sound level is the LAeq,T of the sound source being assessed over the reference time interval, Tr. BS 4142: 2014 advises that Tr should be 1 hour during the day and 15 minutes at night.

The rating level is the specific sound level plus any adjustment for the characteristics of the sound (tone, impulse, intermittent or other acoustic feature). The standard describes subjective and objective methods to establish the appropriate adjustment. The adjustments for the different features and assessment methods are summarised in the table below.

Acoustic Feature Corrections in BS4142: 2014

Acoustic Feature	Adjustment for Acoustic Feature	
	Subjective Methods	Objective Methods
Tonality	+2 dB if just perceptible	Third Octave Analysis
	+4 dB if clearly perceptible +6 dB if highly perceptible	+6 dB if tones identified Narrow Band Analysis Sliding scale of 0 to +6 dB depending on audibility of tone
Impulsivity	+3 dB if just perceptible +6 dB if clearly perceptible +9 dB if highly perceptible	Sliding scale of 0 to +9 dB depending on prominence of impulsive sound



Where tonal and impulsive characters are present in the specific sound within the same reference period then these two corrections can both be taken into account. If one feature is dominant, it might be appropriate to apply a single correction. The rating level is equal to the specific sound level if there are no features present.



The level of impact is assessed by comparing the rating level of the specific sound source with the background sound level. Typically the greater the difference the greater the magnitude of the impact, depending on the context.

Other factors that may require consideration include the absolute level of sound, the character and level of the residual sound compared to the specific sound, and the sensitivity of the receptor and scope for mitigation.

When the rating level is above the background sound level, a difference of around +5 dB is likely to indicate an adverse impact and a difference of around +10 dB or more is likely to indicate a significant adverse impact, depending on the context.

The lower the rating level with respect to the background sound level, the less likely it is that the specific sound source will have an adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context.

3.0 SITE SURVEYS

3.1 SITE DESCRIPTION

The site is located on Theobalds Road. It is typical of an urban cityscape environment, with the dominant source being plant noise. (See Figure 3.1)




Figure 3.1 – Site Location

3.2 ENVIRONMENTAL SITE SURVEY PROCEDURE

24hr noise measurements were carried out (See figure 5.2.1) and logged over the 3rd and 4th August 2022.

The weather was dry and sunny and suitable conditions to carry out the noise survey.



3.3 EQUIPMENT

Instrument manufacturer	Rion
Model	NA-28
Serial Number	00392485
Microphone Type	UC-59
Serial Number	14934
Calibrator	NC-74
Serial Number	34494274
Cirrus CK: 675 Outdoor Kit	

The calibration of the sound level meters was verified in-situ before any measurements were taken, using the handheld calibrator and reference tone of 114dB at 1kHz. Validation checks at the end of the survey indicated that all instruments had operated within permitted tolerances for drift and measured level.

Copies of Calibration certificates can be issue on request.

5.0 NOISE SURVEY

Period	Average LAeq,15	Lowest Recorded LA90, 15
07:00 – 23:00	60dB	39dB
23:00 – 07:00	43dB	39dB

Table 5.1 Lowest recorded Background Noise Level

Period	LA90 Plant Off	LA90 Plant On	LAeq Plant On
15m	42dB	60dB	61dB

Table 5.1.1 – Noise Measurements LAeq,15 at 1m away

5.1 DISCUSSION AND OBSERVATIONS

It can be seen from table 5.1.1 that the existing plant noise exceeds the background noise by 21dB when operating. It can be seen from the Noise Measurements (See Appendix B) that the condenser units were operating 24hrs a day. In the 24hrs recorded, there were four 15min periods where the units were not operating. We have used the lowest L90 level out of these measurements for our calculations for the proposed fan.

6.0 NOISE IMPACT ASSESSMENT

6.1 PROPOSED PLANT

It is understood that the proposed plant is comprised of the following units:

- Flakt Woods - 35 MaXfan Compac

The flue outlet location is shown below in figure 5.2

Proposed Plant	LWA (dB(A))
35 MaXfan Compac	90

Table 5.1 – Manufacturer supplied Sound power level

Fan Description	Ps Sound data at	Pa Static		Sound Spectrum (Hz)								Overall	
				63	125	250	500	1k	2k	4k	8k	Lw*	LpA @ 3m**
31 MaXfan Compac	0.53 m3/s	252	Inlet*	81	79	80	82	80	76	71	66	88	63
31 MaXfan Compac	0.53 m3/s	252	Outlet*	83	80	81	82	80	77	72	67	89	64
31 MaXfan Compac	0.53 m3/s	252	Breakout*	73	68	64	66	61	53	51	47	75	45
35 MaXfan Compac	0.84 m3/s	302	Inlet*	82	80	84	83	80	77	73	69	89	65
35 MaXfan Compac	0.84 m3/s	302	Outlet*	83	80	85	84	81	78	74	69	90	65
35 MaXfan Compac	0.84 m3/s	302	Breakout*	74	68	68	67	60	54	53	51	76	47

6.1.1 INSTALLED PLANT

It is understood that the proposed plant is comprised of the following units:

- Mitsubishi Condenser - Model: FDC140VNA-W
- Mitsubishi Condenser - Model: SRC35ZMP-S
- Mitsubishi Condenser Unit Model: FDC100VNP-W
- Fridger Condenser - P-LSQM026AJW05G
- Embraco Condenser - Model: UNJ9232JK

The flue outlet location is shown below in figure 5.2

Proposed Plant	Spl (dB(A))
FDC140VNA-W	51@1m
SRC35ZMP-S	49@1m
P-LSQM026AJW05G	36@10m
UNJ9232JK	51@1m
FDC100VNP-W	49@1m





Table 5.1 – Manufacturer supplied Sound pressure levels

6.2 CLOSEST NOISE SENSITIVE RECEIVER

The closest noise sensitive receiver to the proposed flue outlet has been identified as being a residential window located approximately 3 meters away from the flue outlet and approximately 2 meters away from the existing condenser units as shown in Figure 6.2.



Figure 6.2 Plant Location

	Location of Proposed Flue Outlet
	Measurement Location
	Nearest Residential Noise Sensitive Window
	Location of existing Condenser Units




Figure 6.2.1 Measurement Location

6.3 NOISE EMISSION CRITERION

It is understood that the proposed operating hours are between 07:00 – 23:00. The criterion has been set as shown in Table 5.3 in order to comply with the Local Authority requirements.

Time Period	Noise Criterion at Nearest Residential Receiver
07:00 – 23:00	29

Table 6.3 - Proposed noise emissions criterion

6.4 MITIGATION MEASURES

6.4.1 – Noise Emissions

In order to achieve the specific sound level and subsequent rating level shown in the assessment above, the following mitigation measures are required.

There are three main noise transmission paths to be considered from the fan to the receptor.

- I. Discharge duct opening.
- II. Fan casing & flexible connection noise break-out.
- III. Duct break-out noise on the fan inlet ducting.

To reduce duct breakout noise on the fan inlet 2 x attenuators are required to be fitted on the discharge side of the fan, similar to an Acoustica CP01-M25-120 with the below insertion losses:

INSERTION LOSS (dB) – CENTRE BAND FREQUENCY								
Hz	63	125	250	500	1K	2K	4K	8K
CP01-M25-120	7	10	15	31	37	38	26	15

The attenuator’s acoustic media shall have to be lined with ‘Melinex’ to enable the kitchen extract system to be regularly steam cleaned.

The fan is located inside the building.



6.4.2 - Vibration

In addition to the control of airborne noise transfer, it is important to consider the transfer of noise as vibration to adjacent properties as well as any sensitive areas of the same building. The duct should be isolated from the structure of the building using anti-vibration. The isolators shall incorporate rubber or neoprene high-frequency isolation pads. The fan should be installed with flexible connections to adjacent structures. Antivibration mounts are widely available from suppliers/installers often in pedestal rubber mountings.

Examples of these are MPO and MP1, and ISL Maxi pedestal vibration mounts. These types of anti-vibration and shock isolators are industry standard and commonplace for mechanical plant installations. They are designed to provide medium to high frequency isolation from vibration and noise via high resilience rubber.

6.4.3 – Existing Condenser Noise Emissions

BS4142:2014 where the RATING level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context. It is determined that the proposed condenser is not considered to contain tones. In addition, the proposed operation of the equipment is also unlikely to be sufficiently intermittent to attract attention at the nearest noise sensitive property.

The calculated rating level is +17dB above the lowest background noise level at 1m from the nearest noise sensitive window.

To meet the noise Criteria DAA Group recommend fully enclosing the condenser units in an acoustic enclosure with an insertion loss of 27dB or greater.

Suitable suppliers include:

Nendle Acoustics – 01252 344222 – admin@nendle.co.uk

Enclosure UK – www.enclosure-uk.com

6.5 BS4142 ASSESSMENT – NEAREST RESIDENTIAL WINDOW

BS4142:2014+A1:2019 Assessment (with mitigation)	
Source	Kitchen Extract Fan
Operating Period	14.00 – 22:00
Reference Time Interval (Tr)	15 minutes
Element	Level (dB)
Specific Sound Level	26
Representative Background Noise Level (LA90)	39
Acoustic feature correction	3
Rating Level	29
Excess of Rating over Background Sound Level	-10

Detailed calculations are shown in Appendix C.



7.0 SUMMARY AND CONCLUSIONS

DAA Group has been appointed to carry out a Noise Impact Assessment at 33 Theobalds Road, WC1X 8SP. The purpose of the survey was to assess the level of noise emanating from the proposed kitchen extraction system and the installed condenser units.

Manufacturer's noise data of proposed extraction fan and installed condensers has been used to obtain Specific and Rated Noise Level at the nearest noise sensitive receiver in accordance with British Standard BS4142:2014 for compliance with Local Authority requirements.

The rating level was compared with the representative background noise level to assess the likelihood of impact considering the environmental noise context of the area as per the requirements of BS4142:2014.

It has been concluded that noise emissions from the proposed plant would not have an adverse impact on the nearest residential receivers provided that the mitigation measures presented in 6.4 is followed.

APPENDIX A ACOUSTIC TERMINOLOGY

B.1 WEIGHTED DECIBEL, dB(A)

The unit generally used for measuring environmental, traffic or industrial noise is the A-weighted sound pressure level in decibels, denoted dB(A). The weighting is based on the frequency response of the human ear and has been found to correlate well with human subjective reactions to various sounds. An increase or decrease of approximately 10 dB corresponds to a subjective doubling or halving of the loudness of a noise, and a change of 2 to 3 dB is subjectively barely perceptible.

B.2 EQUIVALENT CONTINUOUS SOUND LEVEL, LAeq

Another index for assessment for overall noise exposure is the equivalent continuous sound level, LAeq. This is a notional steady level which would, over a given period, deliver the same sound energy as the actual time-varying sound over the same period.

B.3 MAXIMUM NOISE LEVEL, LAmx

The maximum noise level identified during a measurement period. Experimental data has shown that the human ear does not generally register the full loudness of transient sound events of less than 125 ms in duration.

B.4 NOISE RATING, NR

Noise ratings are used as a single figure criterion for specifying services noise in buildings. Each noise rating value has an associated spectrum of defined values in each third or octave frequency band. To determine the noise rating of a room the measured spectrum is compared to a set of noise rating curves. The highest NR curve that crosses any single frequency band of the measurement determines the noise rating for the room.

The single figure noise rating is read at the 1 kHz band.

B.5 SOUND LEVEL DIFFERENCE (D)

The sound insulation required between two spaces may be determined by the sound level difference needed between them. A single figure descriptor which characterises a range of frequencies, the weighted sound level difference, D, is sometimes used (BS EN ISO 717-1). This parameter is not adjusted to reference conditions.

The standardized level difference, Dn, T is a measure of the difference in sound level between two rooms, in each frequency band, where the reverberation time in the receiving room has been normalised to 0.5 s. This parameter measures all transmission paths, including flanking paths.

The weighted standardized level difference, DnTw, is a measure of the difference in sound level between two rooms, which characterises a range of frequencies and is normalised to a reference reverberation time

B.6 SOUND REDUCTION INDEX (R)

The sound reduction index (or transmission loss) of a building element is a measure of the loss of sound through the material, i.e. its attenuation properties. It is a property of the component, unlike the sound level difference which is affected by the common area between the rooms and the acoustic of the receiving room. The weighted sound reduction index, Rw, is a single figure description of sound reduction index characterising a range of frequencies, which is defined in BS EN ISO 717-1: 1997. The Rw is calculated from measurements in an acoustic laboratory

B.7 STATISTICAL NOISE LEVELS ($L_{A90, (T)}$ $L_{A1, (T)}$ $L_{A10, (T)}$ etc.)


For levels of noise that vary widely with time, for example road traffic noise, it is necessary to employ an index which allows for this variation. The L_{A10} is the level exceeded for ten per cent of the time under consideration, has historically been

adopted in the UK for the assessment of road traffic noise. The L_{A90} is the level exceeded for ninety per cent of the time, has been adopted to represent the background noise level. The L_{A1} the level exceeded for one per cent of the time, is representative of the maximum levels recorded during the sample period. A weighted statistical noise levels are denoted $L_{A10, dB}$ $L_{A90, dB}$ etc. The reference time (T) is normally included, e.g. $L_{A10, (5min)}$, & $L_{A90, (8hr)}$.

B.8 TYPICAL NOISE LEVELS

Typical noise levels are given in the following table.

Noise Level dB(A)	Example
130	Threshold of pain
120	Jet aircraft take-offs at 100 m
110	Chain saw at 1 m
100	Inside disco
90	Heavy lorries at 5 m
80	Kerbside of busy street
70	Loud radio (in typical domestic room)
60	Office or restaurant
50	Domestic fan heaters at 1m
40	Living room
30	Ventilation Noise in Theatre
20	Remote countryside on still night
10	Sound insulated test chamber
0	Threshold of hearing.





APPENDIX C - CALCULATIONS

33 Theobalds Road. External Noise Transmission.														
Kitchen Extract System.														
NOISE EMISSION CALCULATION														
ITEM	PARAMETER				HZ	63	125	250	500	1K	2K	4K	8K	dB A
1	Schedule of Plant		Qty											
2														
3	Model: MaxFan 35		1	Swl	dB +	83	80	85	84	81	78	74	69	90
4	Ductwork natural losses		Lot	IL	dB -	15	10	3	2	6	8	8	9	
5	Discharge Attenuator Model: CP01-M25-120	Primary	1	IL	dB -	7	10	15	31	37	38	26	15	
6	Discharge Attenuator Model: CP01-M25-120	Secondary	1	IL	dB -	7	10	15	31	37	38	26	15	
7														
8														
9														
10														
11	Revised Sound Power Level:		1	Swl	dB +	54	50	52	20	1	-6	14	30	44
12														
13														
14														
15	Distance to nearest receptor Metres:	r	3		dB -	18	18	18	18	18	18	18	18	18
16	SPL=SWL -20log(r) + 10log(Q) -11 dB.		Q	2										
17														
18														
19														
20	Spl at receptor				dB +	36	32	34	2	-17	-24	-4	12	26
21														
22														
23	Façade correction		3		dB +	3	3	3	3	3	3	3	3	3
24														
25														
26														
27	Specific noise level at receptor				dB +	39	35	37	5	-14	-21	-1	15	29
28	(1m outside noise sensitive window)													
29	Lowest Background Noise Levels: (L_{A90})													
30	Daytime (07:00-23:00)				dB +									39
31	Difference: (Daytime Assessment level)				dB -									-10
32														
33														
34														
35														
36														
	E&OE													


NOISE EMISSION CALCULATION														
ITEM	PARAMETER			HZ		63	125	250	500	1K	2K	4K	8K	dBA
1	Schedule of Plant	Qty												
2	FDC100VNP-W	1	Spl	dB	+	52	48	48	45	46	33	29	29	49
3	FDC140VNA-W	1	Spl	dB	+	55	52	51	48	47	39	40	35	51
	SRC35ZMP-S	1	Spl	dB	+	55	50	49	46	44	39	36	29	49
4	P-LSQM026AJW05G	1	Spl	dB	+	69	65	53	51	49	45	44	42	56
5	UNJ9232JK	1	Spl	dB	+	55	52	51	48	47	39	40	35	51
6	Revised Spl:	1	Spl	dB	+	70	67	58	55	53	47	47	44	59
7														
8														
9														
10														
11	Distance to nearest receptor Metres:	2		dB	-	-6	-6	-6	-6	-6	-6	-6	-6	-6
12	$SPL=L1-20\log_{10}(r2/r1)$	1												
13														
14	Natural Barrier		∅	dB	-	0	0	0	0	0	0	0	0	0
15														
16	Spl at receptor			dB	+	64	61	52	49	47	41	41	38	53
17														
18														
19	Façade correction	3.0		dB	+	3	3	3	3	3	3	3	3	3
20	Intermittant noise correction	0		dB	+	0	0	0	0	0	0	0	0	0
21														
22														
23	Specific noise level at receptor			dB	+	67	64	55	52	50	44	44	41	56
24	(1m outside noise sensitive window)													
25	Lowest Background Noise Levels:(L _{A90})													
26	Night Time (23:00-07:00)													39
27	Difference: (Assessment level)			dB	-									17
28														
29	Daytime (07:00-23:00)													39
30	Difference: (Assessment level)			dB	-									17
	E&OE													

APPENDIX D – NOISE DATA

(Outdoor Unit)


Model	SRC35ZMP-S	
Noise Level	Cooling	49 dB(A)
	Heating	48 dB(A)

• Mike position: at highest noise level in position as mentioned below
Distance from front side 1m



Models FDC140VN,140VS

Noise level 51 dB (A)



Models FDC100VN,100VS

Noise level 49 dB (A)

