

Cinders
66 Belsize Lane
Belsize Park
London
NW3 5BJ

Maintenance and cleaning Schedule

1. The extraction canopy and stainless steel filters should be cleaned weekly
2. The Pre Filter should be replaced weekly
3. The odour control system should be serviced once a year as per manufacture recommendations
4. As per Tr19 the extraction system and ductwork cleaning should be scheduled every 4 months

Regards
Scott Robinson
Director