

## Project name

**Bedford Row\_220912**

As designed

Date: Tue Oct 11 16:21:10 2022

## Administrative information

## Building Details

Address: Address 1, Address 2, City, Postcode

## Certification tool

Calculation engine: SBEM

Calculation engine version: v5.6.b.0

Interface to calculation engine: Virtual Environment

Interface to calculation engine version: v7.0.17

BRUKL compliance check version: v5.6.b.0

## Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Criterion 1: The calculated CO<sub>2</sub> emission rate for the building must not exceed the target

CO <sub>2</sub> emission rate from the notional building, kgCO <sub>2</sub> /m <sup>2</sup> .annum	20.5
Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> .annum	20.5
Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> .annum	12.3
Are emissions from the building less than or equal to the target?	BER =< TER
Are as built details the same as used in the BER calculations?	Separate submission

## Criterion 2: The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Values which do not achieve the standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

## Building fabric

Element	U <sub>a</sub> -Limit	U <sub>a</sub> -Calc	U <sub>i</sub> -Calc	Surface where the maximum value occurs*
Wall**	0.35	0.31	1.79	"ST00002D_W4_A0"
Floor	0.25	1	1.09	"ST00004E_F_A0"
Roof	0.25	0.18	0.18	"ST00002D_C"
Windows***, roof windows, and rooflights	2.2	1.6	1.6	"ST00002D_W5_O0"
Personnel doors	2.2	2.2	2.2	"ST00004F_W1_O1"
Vehicle access & similar large doors	1.5	-	-	"No external vehicle access doors"
High usage entrance doors	3.5	-	-	"No external high usage entrance doors"
U <sub>a</sub> -Limit = Limiting area-weighted average U-values [W/(m <sup>2</sup> K)] U <sub>a</sub> -Calc = Calculated area-weighted average U-values [W/(m <sup>2</sup> K)] U <sub>i</sub> -Calc = Calculated maximum individual element U-values [W/(m <sup>2</sup> K)]				
* There might be more than one surface where the maximum U-value occurs.				
** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.				
*** Display windows and similar glazing are excluded from the U-value check.				
N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.				

Air Permeability	Worst acceptable standard	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	10	5

## Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	YES
Whole building electric power factor achieved by power factor correction	<0.9

1- Be Green VRF with Instant (Copy)

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	4.02	2.6	-	-	-
<b>Standard value</b>	2.5*	2.6	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					YES
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. For types <=12 kW output, refer to EN 14825 for limiting standards.					

1- SYST0006-DHW

	Water heating efficiency	Storage loss factor [kWh/litre per day]
<b>This building</b>	1	-
<b>Standard value</b>	1	N/A

### Local mechanical ventilation, exhaust, and terminal units

ID	System type in Non-domestic Building Services Compliance Guide
A	Local supply or extract ventilation units serving a single area
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal supply and extract ventilation units serving a single room or zone with heating and heat recovery
E	Local supply and extract ventilation system serving a single area with heating and heat recovery
F	Other local ventilation units
G	Fan-assisted terminal VAV unit
H	Fan coil units
I	Zonal extract system where the fan is remote from the zone with grease filter

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I	Zone	Standard
<b>Standard value</b>		0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1		
02_LB Office		-	-	-	1.9	-	-	-	-	-	0.7	0.5
03_JF Office		-	-	-	1.9	-	-	-	-	-	0.7	0.5
03_WC 2		-	-	0.4	-	-	-	-	-	-	-	N/A
03_Plant		-	-	0.4	-	-	-	-	-	-	-	N/A
04_BR Office		-	-	-	1.9	-	-	-	-	-	0.7	0.5

### General lighting and display lighting

Zone name	Luminous efficacy [lm/W]			General lighting [W]
	Luminaire	Lamp	Display lamp	
<b>Standard value</b>	60	60	22	
02_LB Office	110	-	-	790
02_Fire Stair	-	110	-	12
03_JF Office	110	-	-	1179
03_Staircase 2	-	110	-	33
03_Lift 2	110	-	-	6
03_WC 2	-	110	-	36

General lighting and display lighting		Luminous efficacy [lm/W]			
Zone name		Luminaire	Lamp	Display lamp	General lighting [W]
	<b>Standard value</b>	60	60	22	
03_Dry Riser 2		110	-	-	8
03_Fire Escape 2		-	110	-	34
03_Plant		110	-	-	50
03_Fire Escape		-	110	-	25
04_BR Office		110	-	-	710
04_Circulation		-	110	-	13
04_Lift		110	-	-	6
04_Staircase		-	110	-	23
02_Lobby 1		-	110	-	11

### Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
02_LB Office	YES (+0.9%)	NO
02_Fire Stair	N/A	N/A
03_JF Office	NO (-82.8%)	NO
03_Staircase 2	NO (-75%)	NO
03_Lift 2	N/A	N/A
03_WC 2	N/A	N/A
03_Dry Riser 2	N/A	N/A
03_Fire Escape 2	NO (-58.7%)	NO
03_Plant	N/A	N/A
03_Fire Escape	N/A	N/A
04_BR Office	NO (-92.4%)	NO
04_Circulation	N/A	N/A
04_Lift	N/A	N/A
04_Staircase	N/A	N/A
02_Lobby 1	N/A	N/A

### Criterion 4: The performance of the building, as built, should be consistent with the calculated BER

Separate submission

### Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place

Separate submission

### EPBD (Recast): Consideration of alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	NO
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	NO

# Technical Data Sheet (Actual vs. Notional Building)

## Building Global Parameters

	Actual	Notional
Area [m <sup>2</sup> ]	592	592
External area [m <sup>2</sup> ]	1074.3	1074.3
Weather	LON	LON
Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa]	5	3
Average conductance [W/K]	434.75	471.25
Average U-value [W/m <sup>2</sup> K]	0.4	0.44
Alpha value* [%]	17.91	43.25

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Building Use

### % Area Building Type

	A1/A2 Retail/Financial and Professional services
	A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways
<b>100</b>	<b>B1 Offices and Workshop businesses</b>
	B2 to B7 General Industrial and Special Industrial Groups
	B8 Storage or Distribution
	C1 Hotels
	C2 Residential Institutions: Hospitals and Care Homes
	C2 Residential Institutions: Residential schools
	C2 Residential Institutions: Universities and colleges
	C2A Secure Residential Institutions
	Residential spaces
	D1 Non-residential Institutions: Community/Day Centre
	D1 Non-residential Institutions: Libraries, Museums, and Galleries
	D1 Non-residential Institutions: Education
	D1 Non-residential Institutions: Primary Health Care Building
	D1 Non-residential Institutions: Crown and County Courts
	D2 General Assembly and Leisure, Night Clubs, and Theatres
	Others: Passenger terminals
	Others: Emergency services
	Others: Miscellaneous 24hr activities
	Others: Car Parks 24 hrs
	Others: Stand alone utility block

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

	Actual	Notional
Heating	4.85	8.68
Cooling	5.04	8.59
Auxiliary	4.98	2.68
Lighting	9.31	18.9
Hot water	2.36	2.73
Equipment*	40.38	40.38
<b>TOTAL**</b>	<b>26.54</b>	<b>41.59</b>

\* Energy used by equipment does not count towards the total for consumption or calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

	Actual	Notional
Photovoltaic systems	2.75	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0

## Energy & CO<sub>2</sub> Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m <sup>2</sup> ]	158.71	187.29
Primary energy* [kWh/m <sup>2</sup> ]	81.47	119.3
Total emissions [kg/m <sup>2</sup> ]	12.3	20.5

\* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

## HVAC Systems Performance

System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER
[ST] Split or multi-split system, [HS] Heat pump (electric): air source, [HFT] Electricity, [CFT] Electricity									
Actual	68.9	89.8	4.9	5	5	3.94	4.96	4.02	6.63
Notional	75.9	111.4	8.7	8.6	2.7	2.43	3.6	----	----

### Key to terms

Heat dem [MJ/m2]	= Heating energy demand
Cool dem [MJ/m2]	= Cooling energy demand
Heat con [kWh/m2]	= Heating energy consumption
Cool con [kWh/m2]	= Cooling energy consumption
Aux con [kWh/m2]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type

# Key Features

The Building Control Body is advised to give particular attention to items whose specifications are better than typically expected.

## Building fabric

Element	U <sub>i-Typ</sub>	U <sub>i-Min</sub>	Surface where the minimum value occurs*
Wall	0.23	0.26	"ST00002D_W5"
Floor	0.2	0.22	"ST000052_F"
Roof	0.15	0.18	"ST00002D_C"
Windows, roof windows, and rooflights	1.5	1.6	"ST00002D_W5_O0"
Personnel doors	1.5	2.2	"ST00004F_W1_O1"
Vehicle access & similar large doors	1.5	-	"No external vehicle access doors"
High usage entrance doors	1.5	-	"No external high usage entrance doors"
U <sub>i-Typ</sub> = Typical individual element U-values [W/(m <sup>2</sup> K)]		U <sub>i-Min</sub> = Minimum individual element U-values [W/(m <sup>2</sup> K)]	
* There might be more than one surface where the minimum U-value occurs.			

Air Permeability	Typical value	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	5	5