

<b>Application No:</b>	<b>Consultees Name:</b>	<b>Received:</b>	<b>Comment:</b>	<b>Response:</b>
2022/3677/P	Belsize Society by Tom Symes	31/10/2022 16:31:05	OBJ	There is already an air conditioning condenser at the property. The proposal is to add another. The noise impact assessment was carried out when the existing condenser was not operational - para 3.2. Does this make its conclusions meaningless since presumably the noise levels will be at their highest when both condensers are running at the same time?

---