

Ryan Ward
 Town Planning Lead
 Mace Dragados HS2 Project Office

Patrick Marfleet

Senior Planning Officer
 Regeneration and Planning
 London Borough of Camden
Sent via email

24 November 2022

Dear Patrick,

Application for the erection of a six-storey combined Construction Skills Centre (Use Class F1) and HS2 Site Accommodation (Use Class (E) as temporary meanwhile uses to facilitate the construction of HS2 Euston Station (your ref: 2021/3796/P)

I am writing on behalf of High Speed Two (HS2) Limited in relation to the approved planning application for a Construction Skills Centre and Site Accommodation at the former Maria Fidelis School site.

Please find enclosed in this application a package of drawings and information required to discharge condition 12 of the planning permission, which states:

Prior to occupation evidence that an appropriate PM filtration system on the mechanical ventilation intake of the building has been installed, and a detailed mechanism to secure maintenance of this system and changing of filters, should be submitted to the Local Planning Authority and approved in writing.

The accompanying submitted drawings / documents are listed below for reference.

Reference Number	Drawing / Document Title	Revision Number
1CP01-MDS_PML-ME-SPE-SS08_SL23-000034	Purified Air Specification and Information to discharge Condition 12 'NO2 Filtration' of permission 2021/3796/P	C01
1CP01-MDS_PML-ME-DGA-SS08_SL23_F6-000008	Roof Ventilation Layout (1 of 2)	C04
1CP01-MDS_PML-ME-DGA-SS08_SL23_F6-000007	Roof Ventilation Layout (2 of 2)	C04

HS2-HS2-CO-TEM-000-000067 P01

1CP01-MDS_PML-ME-DGA-SS08_SL23_F6-000009	Roof Plantroom	C05
--	----------------	-----

The planning application fee of £116 has been paid via the Planning Portal. Please do not hesitate to contact me if you have any queries, and I look forward to receiving written confirmation that the condition has been discharged.

Yours sincerely



Ryan Ward
Town Planning Lead
Mace Dragados HS2 Project Office