



NOTES

1. ALL DUCTWORK SYSTEMS INSTALLED IN ACCORDANCE WITH DW144 SPECIFICATION FOR SHEET METAL DUCTWORK FOR LOW PRESSURE "CLASS A" SYSTEMS.

2. ALL DUCTWORK MANUFACTURED FROM HOT DIP GALVANISED STEEL TO BS EN101:1991, UNLESS NOTED OTHERWISE ON THE DRAWINGS.

3. RECTANGULAR DUCTWORK CROSS JOINTS SHOULD BE SEALED IN ACCORDANCE WITH DW144 FIGS 10, 13&14, FASTENINGS AND MAXIMUM SPACINGS IN ACCORDANCE WITH SECTION 10.7.

4. CIRCULAR DUCTWORK SPIRAL WOUND AND STRAIGHT SEAMED JOINTS SEALED IN ACCORDANCE WITH DW144 FIGS 32-45, FASTENINGS AND MAXIMUM SPACINGS IN ACCORDANCE WITH SECTION 13.3.

5. ACCESS PANELS PROVIDED ADJACENT TO ALL FIRE DAMPERS, UNLESS, REMOTE ACCESS TYPE COMBINED FIRE DAMPER VCD'S ARE TO BE USED.
6. ALL ACCESS/INSPECTION HATCHES ARE PROPRIETARY MANUFACTURED WITH QUICK RELEASE CATCHES AND SELF SEALING GASKETS.

7. ALL ACCESS/INSPECTION PANELS REMAIN ACCESSIBLE, THE INSULATION CONTRACTOR HAS SUITABLY DRESSED THE EDGES OF THE INSULATION TO THE EDGE OF THE ACCESS OPENING.

8. THE USE OF FLEXIBLE DUCTWORK IS LIMITED TO 1000mm IN LENGTH TO MAKE FINAL CONNECTIONS ONLY - NOTE ADDITIONAL LENGTH MAY BE REQUIRED TO ALLOW TRANSITION TO PLENUM CONNECTIONS IN SOME AREAS.

9. DUCTWORK MANUFACTURED WITH GRADUAL TRANSFORMATIONS AND CHANGES OF SHAPE/DIRECTION, ACCORDANCE WITH SECTION 13.3.

10. FLEXIBLE CONNECTIONS INCORPORATED WITHIN THE DUCTWORK SYSTEM FROM VIBRATION PRODUCING EQUIPMENT.
11. GRILLES AND DIFFUSERS PROVIDED WITH SUITABLE PURPOSE MADE PLENUM BOXES (SIDE OR TOP ENTRY SPIGOT AS NECESSARY) WHERE INDICATED.

12. ALL GRILLES AND DIFFUSERS PROVIDED WITH BALANCING DAMPERS WITHIN THE DUCTWORK SERVING THE GRILLE OR DIFFUSER - SINGLE LEAF TYPE ON FINAL BRANCHES.

13. ALL GRILLES AND DIFFUSERS HAVE A FINISH COLOUR TO SUIT THE ARCHITECT'S REQUIREMENTS.

14. ALL AIR DISTRIBUTION DUCTS PASSING THROUGH ELEMENTS OF STRUCTURE FORMING FIRE COMPARTMENTS SHALL INCORPORATE A FIRE DAMPER, OR COMBINED FIRE AND SMOKE DAMPERS TO PREVENT SMOKE MIGRATION TO EMERGENCY ESCAPE ROUTES. DAMPER RATINGS SHALL BE AS PER THE FIRE STRATEGY DRAWING: 30min, 60min OR 90min.
15. FIRE DAMPERS, OR COMBINED FIRE AND SMOKE DAMPERS SHALL BE PROVIDED IN THE LOCATIONS AS INDICATED ON THE DRAWINGS. THE SMOKE DAMPER PANEL SHALL BE LOCATED ADJACENT THE FIRE ALARM PANEL SERVING THE CSC AND SA AREAS.

16. THE FIRE DAMPER BLADE IS OF STAINLESS STEEL CONSTRUCTION AND SHALL BE HELD IN THE OPEN POSITION BY MEANS OF A THERMAL RELEASE MECHANISM RATED AT 72°C +/- 2°C.

17. ALL BRANCHES FROM THE MAIN DISTRIBUTION DUCTS ARE BY A SMOKE-BRANCH FITTINGS.

18. ALL FRESH AIR INTAKE DUCTWORK IS INSULATED, VAPOUR SEALED AND WEATHERPROOFED WHERE NECESSARY (ATMOSPHERE SIDE ONLY AND/OR WHERE AIR SUPPLIED IS USED TO PROVIDE SPACE HEATING/COOLING). THE INSULATION HAS AN ENVIRONMENTAL THICKNESS BETWEEN 20MM AND 50MM (TO SUIT THE IN DUCT AND AMBIENT AIR TEMPERATURES) WITH A MAXIMUM THERMAL CONDUCTIVITY OF 0.035 W/mK.
19. ALL ROOM SIDE DUCTWORK SYSTEMS, AND EXHAUST DUCTWORK SYSTEMS, ARE TO BE FULLY INSULATED; DISTRIBUTION OF CONDITIONED AIR WITH HEAT RECOVERY SYSTEMS.

20. UPON COMPLETION OF THE WHOLE VENTILATION INSTALLATION THE SYSTEM IS BALANCED AND COMMISSIONED IN ACCORDANCE WITH CIBSE COMMISSIONING CODE A.

LEGEND

- SUPPLY / EXTRACT GRILLE - CIRCULAR
- SUPPLY / EXTRACT GRILLE - RECTANGULAR
- FLEXIBLE DUCTWORK CONNECTION
- COMBINED FIRE / SMOKE DAMPER
- FIRE DAMPER
- VOLUME CONTROL DAMPER - RECTANGULAR
- VOLUME CONTROL DAMPER - CIRCULAR
- RISING / DROPPING DUCTWORK
- ATTENUATOR - CIRCULAR
- ATTENUATOR - RECTANGULAR
- AIR TRANSFER / FLOW DIRECTION

C05	BMS PANEL SIZE UPDATED	JB	JW	MMc	HS2 accepts no responsibility for any circumstances which arise from the reproduction of this document after alteration, amendment or abbreviation or if it is issued in part or issued incompletely in any way.
C04	BMS PANEL SIZE UPDATED	JB	JW	MMc	© Crown Copyright and database right 2020. All rights reserved. Ordnance Survey Licence number 100049150.
C03	STAGE 5 ISSUE	JB	JW	MMc	© Crown Copyright material is reproduced with the permission of Land Registry under delegated authority from the Controller of HMSO. This material was last updated on 2020 and may not be copied, distributed, sold or published without the formal permission of Land Registry. Only an official copy of a title plan or register obtained from the Land Registry may be used for legal or other official purposes.
C02	STAGE 4 ISSUE	JB	JW	MMc	
C01	PRELIMINARY ISSUE FOR COMMENT	JB	JW	MMc	
Rvw	Description	Drawn	Checked	Approved	Con App

Legends/Notes:

Scale with caution as distortion can occur.

HS2

OFFICIAL  
Registered in England  
Registration No. 06791686  
Registered office:  
2 Snow Hill, Queensway,  
Birmingham, B4 6GA

Stage	5	Project/Contract	Euston Station	Creation/Originator	PREMIER MODULAR	Sub-Originator	
Drawing Title	ROOF	Work Package Description	1200503	Discipline/Function	COMBINED MEP	System Description	
Drawing Title	PLANTROOM	Drawn by	JB	Checked by	JW	Approved by	MMc
1 of 2		Scale	1:50	Size	A0	Suitability	S4
		Date	30.11.21	Rev.	C05		
Drawing No.	1CP01-MDS_PML-ME-DGA-SS08_SL23_F8-000009						