

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

SUPPLY CHARACTERISTICS

System type(s)	Number and type of live conductors	Nature of supply parameters	Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one supply, record the higher or highest values			
TN-S ✓	1-phase (2-wire) N/A	Number of sources: 1	Nominal U ⁽¹⁾ (voltagess)	240V	Nominal frequency, f ⁽¹⁾	50 Hz
TN-C-S N/A	3-phase (3-wire) ✓	Nominal U ⁽¹⁾	U _n	0 V	External earth fault loop impedance, Z _s ⁽²⁾	0.8 Ω
TT N/A	Other Phase state N/A	Prospective fault current, I _{pf} ⁽³⁾	3.5 kA	3-phase Prospective fault current, I _{pf} ⁽³⁾	N/A	kA
			Characteristics of primary supply overcurrent protective device(s) Type: IPB Rated current: 100 A Short-circuit capacity: 33 kA			

PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of earthing	Details of installation earth electrode (where applicable)	Main protective bonding conductors and bonding of extraneous-conductive parts (*)		Measured Z _s	Maximum demand (load)	Number of smoke alarms	Other incoming services(s)
Distributor's facility ✓	Type (eg rods/s, tape etc) N/A	Water service ✓	Oil service ✓	0.23 Ω	20 kVA	3	Gas service ✓
Installation earth electrode N/A	Electrode resistance, R _a N/A	Structural steel ✓		4.5 Ω			
Earthing conductor	Continuity/connection verified ✓						
Conductor material: copper	Conductor material: copper						
Conductor csa: 16 mm ²	Conductor csa: 16 mm ²						
Continuity/connection verified ✓	Location: (where not obvious) ✓						
	Method of measurement: N/A						

SCHEDULE OF ITEMS INSPECTED

Protective measures against electric shock	Additional protection	Cables and conductors (cont)
Basic and fault protection ✓	Presence of residual current device(s) ✓	Routing of cables in prescribed zones ✓
Extra-low voltage ✓	Presence of supplementary bonding conductors ✓	Cables incorporating earthed armour or sheath, or run in an earthed wiring system, or otherwise adequately protected against nails, screws and the like ✓
Double or reinforced insulation ✓	Prevention of mutual detrimental influence	Additional protection by 30 mA RCD (where required, in premises not under the supervision of a skilled or instructed person) ✓
Basic protection ✓	Proximity of non-electrical services and other influences ✓	Connection of conductors ✓
Insulation of live parts ✓	Segregation of Band I and Band II circuits or Band II insulation used ✓	Presence of fire barriers, suitable seals and protection against thermal effects ✓
Fault protection ✓	Segregation of safety circuits ✓	General
Automatic disconnection of supply ✓	Identification	Presence and correct location of appropriate devices for isolation and switching ✓
Presence of earthing conductor ✓	Presence of diagrams, instructions, circuit charts and similar information ✓	Adequacy of access to switchgear and other equipment ✓
Presence of circuit protective conductors ✓	Presence of danger notices ✓	Particular protective measures for special installations and locations ✓
Presence of main protective bonding conductors ✓	Presence of other warning notices, including presence of mixed wiring colours ✓	Connection of single-pole devices for protection or switching in line conductors only ✓
Presence of adequate arrangements for other source(s), where applicable ✓	Labelling of protective devices, switches and terminals ✓	Correct connection of accessories and equipment ✓
Choice and setting of protective devices (for fault protection and/or overcurrent) ✓	Identification of conductors ✓	Selection of equipment and protective measures appropriate to external influences ✓
Electrical separation ✓	Selection of conductors for current-carrying capacity and voltage drop ✓	Selection of appropriate functional switching devices ✓
For one item of current-using equipment ✓	Erection methods ✓	

SCHEDULE OF ITEMS TESTED

External earth fault loop impedance, Z _s ✓	Installation earth electrode resistance, R _a ✓	Continuity of protective conductors ✓	Continuity of ring final circuit conductors ✓	Insulation resistance between live conductors and earth ✓	Insulation resistance between live conductors and earth ✓	Earth fault loop impedance, Z _s ✓	Verification of phase sequence ✓	Operation of residual current device(s) ✓	Functional testing of assemblies ✓	Verification of voltage drop ✓
---	---	---------------------------------------	---	---	---	--	----------------------------------	---	------------------------------------	--------------------------------

* applicable only where an RCD is used as a main circuit-breaker

† See note below

† See note below



DOMESTIC INSTALLER

This safety certificate is an important and valuable document which should be retained for future reference

DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with British Standard 7671 - Requirements for Electrical Installations by a Domestic Installer registered with NICEIC.

This certificate is not valid if the serial number has been defaced or altered
DCP5/ 0085255

DETAILS OF THE CLIENT

Client and address
GIBALD
88 Newmans
Barnham - Great Clarendon

Postcode
M66 1NL

ADDRESS OF THE INSTALLATION

Installation address
7 Belsize Square

This same

Postcode
M23 4AX

DETAILS OF THE INSTALLATION

Extent of the installation work covered by this certificate
NEW INSTALLATION - 2nd FIX ONLY
1st FIX DONE BY OTHER CONTRACTOR

The installation is
New YES
An addition NO
An alteration NO

DESIGN, CONSTRUCTION, INSPECTION AND TESTING

I/we, being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my/our signature adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I/we have been responsible is, to the best of my/our knowledge and belief, in accordance with BS 7671, 2008 amended to 2012 (date) except for the departures, if any, detailed as follows:
Details of departures from BS 7671, as amended (Regulations 120.3, 133.5)
NONE

The extent of liability of the signatory is limited to the work described above as the subject of this certificate. For the DESIGN, the CONSTRUCTION and the INSPECTION AND TESTING of the installation

The results of the inspection and testing reviewed by the Qualified Supervisor

Signature: [Signature] Name (CAPITALS): PARZYNSKI Date: 4.07.12
Signature: [Signature] Name (CAPITALS): PARZYNSKI Date: 4.07.12

NEXT INSPECTION

5. Enter interval in terms of years, months or weeks, as appropriate

I RECOMMEND that this installation is further inspected and tested after an interval of not more than 5 years

COMMENTS ON EXISTING INSTALLATION

NONE

Note: Enter NONE or where appropriate, the page number(s) of additional page(s) of comments on the existing installation

In the case of an alteration or additions see Section 633 of BS 7671

PARTICULARS OF THE DOMESTIC INSTALLER

Trading title
PORE ENERGY PROJECT LTD
Address
72A BRAEMAR AVENUE
LONDON

Telephone No 07825268434 Postcode NW10 0DL

NICEIC Registration No 115139-1
(essential information)

SCHEDULE OF ADDITIONAL RECORDS*

See attached schedule

NONE

* Where the electrical work to which this certificate relates includes the installation of a fire alarm system and/or an emergency lighting system (or a part of such systems), this electrical safety certificate should be accompanied by the particular certificate(s) for the system(s)

This certificate is based on the model forms shown in Appendix 6 of BS 7671.

Published by NICEIC



DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

This certificate is not valid if the serial number has been defaced or altered

DCP5/ 0085255

Original (To the person ordering the work)

Circuit number	Circuit description	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: cat		Max. disconnection time permitted by BS 7671 (s)	Overcurrent protective devices		RCD	Circuit impedances		Insulation resistance		Polarity	Maximum measured earth fault loop impedance, Z _s (Ω)	RCD		Test button operation								
					Live (mm ²)	CPC (mm ²)		BS (EN)	Type		Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum Z _s permitted by BS 7671 (Ω)			R ₁ (line) (Ω)	R ₂ (neutral) (Ω)		All circuits (At least one column to be completed)	R ₁	R ₂	Line/line (MΩ)	Line/neutral (MΩ)	Line/earth (MΩ)	Neutral/earth (MΩ)	at 1kV (ms)
1	FLOOR LIGHTS	A	C	15	1.0	0.5	60898	B	6	30	6.13	N/A	N/A	N/A	N/A	1.09	N/A	N/A	7199	7199	7199	7199	1.37	362	144	✓	
	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7199	7199	7199	7199	N/A	362	144	✓
	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7199	7199	7199	7199	N/A	362	144	✓
4	BOILER/WATER HEATER	A	C	1	2.5	1.5	60898	B	6	30	1.15	N/A	N/A	N/A	N/A	0.93	N/A	N/A	7199	7199	7199	7199	0.93	362	144	✓	
5	SPUR RING KITCHEN SPARE	A	C	4	2.5	1.5	60898	B	6	30	1.15	N/A	N/A	N/A	N/A	0.78	N/A	N/A	7199	7199	7199	7199	0.78	362	144	✓	
7	FLOOR SKIS/ROOF	A	C	4	2.5	1.5	60898	B	32	6	30	1.15	0.83	0.83	1.41	0.61	N/A	N/A	7199	7199	7199	7199	1.09	362	144	✓	
8	GROUND 1st FLOOR SKITS	A	C	10	2.5	1.5	60898	B	32	6	30	1.5	0.53	0.53	0.88	0.35	N/A	N/A	7199	7199	7199	7199	1.08	364	142	✓	
9	LIGHTS GR FLOOR BATH	A	C	25	1.5	1.0	60898	B	6	30	6.13	N/A	N/A	N/A	N/A	1.67	N/A	N/A	7199	7199	7199	7199	1.62	364	142	✓	
10	FLOOR LIGHTS	A	C	12	1.5	1.0	60898	B	6	30	6.13	N/A	N/A	N/A	N/A	1.67	N/A	N/A	7199	7199	7199	7199	1.62	364	142	✓	
11	STORES	A	C	3	1.5	1.0	60898	B	6	30	6.13	N/A	N/A	N/A	N/A	0.81	N/A	N/A	7199	7199	7199	7199	1.12	364	142	✓	
	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7199	7199	7199	7199	N/A	364	142	✓	
13	KITCHEN SPARE	A	C	4	2.5	1.5	60898	B	32	6	30	1.15	0.38	0.37	0.62	0.26	N/A	N/A	7199	7199	7199	7199	0.63	364	142	✓	
14	KITCHEN SKITS	A	C	3	2.5	1.5	60898	B	32	6	30	1.15	0.45	0.43	0.73	0.31	N/A	N/A	7199	7199	7199	7199	0.65	364	142	✓	
15	OVEN	A	C	1	6	2.5	60898	B	6	30		N/A	N/A	N/A	N/A	0.17	N/A	N/A	7199	7199	7199	7199	0.57	364	142	✓	

Location of consumer unit: ceiling Designation of consumer unit: DB 1 Prospective fault current at consumer unit: 1.1 KA

TEST INSTRUMENTS: Multi-function: 1344230 Insulation resistance: N/A Continuity: N/A Earth electrode resistance: N/A Earth fault loop impedance: N/A RCD: N/A

CODES FOR TYPE OF WIRING: A Thermoplastic insulated/sheathed cables, B Thermoplastic cables in metallic conduit, C Thermoplastic cables in metallic trunking, D Thermoplastic cables in non-metallic trunking, E Thermoplastic cables in non-metallic trunking, F Thermoplastic/SWA cables, G Thermosetting/SWA cables, H Mineral-insulated cables, O (Other - please state)



DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT

Small installations up to 100 A single phase supply

This report is not valid if the serial number has been defaced or altered

21490373

DPN18C

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR

Registration No: 600995000 Branch No: 000
Trading Title: Mega 2 Limited
Address: 94-96 Seymour Place, London
Postcode: W1H 1NB Tel No: 0207 7242244

DETAILS OF THE CLIENT

Contractor Reference Number (CRN): N/A
Name: Mr Gerald Barrett
Address: 22 Fortis green avenue, Muswellhill, London
Postcode: N2 9NA Tel No: N/A

DETAILS OF THE INSTALLATION

Occupier: Void property
Address: 7 Belsize Terrace, Hampstead, London
Postcode: NW3 4AX Tel No: N/A

PART 2 : PURPOSE OF THE REPORT

Purpose for which this report is required: Landlords requirement

Date(s) when inspection and testing was carried out: (3/07/2020) Records available: (X) Previous inspection report available: (X) Previous report date: (N/A)

PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety): average for its age

Estimated age of electrical installation: (10) years Evidence of additions or alterations: (X) Overall assessment of the installation is: **Satisfactory** ~~XXXXXXXXXX~~ (delete as appropriate)

PART 4 : DECLARATION

INSPECTION AND TESTING

I, being the person responsible for the inspection and testing of the electrical installation, particulars of which are described in PART 7, having exercised reasonable skill and care when carrying out the inspection and testing of the existing installation, hereby CERTIFY that the information in this report, including the observations (page 2) and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing.

Name (capital): JASON SCALES

Signature: Jason Scaler Date: 17/07/2020

REVIEWED BY QUALIFIED SUPERVISOR

Name (capital): JASON SCALES

Signature: Jason Scaler Date: 17/07/2020

*An unsatisfactory assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified in PART 6, or that further investigation (CODE F1) without delay is required.